

MP

Ack

Sent: 24 November 2011 12:33
To: Planning
Subject: Comments Added: Salisbury Square, Hatfield

Dear Development

Please be aware that comments have been added to the following application:

Application Details:

Application ID: S6/2011/1994/MA Mr M Peacock Application Owner: Welwyn & Hatfield Borough Council(Development Control Officer)
Applicant: JB Planning Associates Ltd
Location: Salisbury Square, Hatfield
Deadline Date: 25/11/2011 00:00:00
Description: .
Comment Added:

Commented By: administration.cfs@hertsgov.uk

Comment: Emergency appliance access should be in accordance with Section B5 of Approved Document B.

We reserve comment on water supplies until scaled drawings of water main extensions are received by our Water Section at Service Headquarters.

Fred Baker
Fire Safety Inspector

Please click the following link to review these comments:

<http://www.consultlive.co.uk/index.aspx?appID=7891>

Any reply to this email will be logged against the consultation.

If you have problems with this link, please email the Consult-Live help team - helpdesk@resolutiondm.com quoting reference: EM004

Powered by DataSpace Consult Live www.consultlive.co.uk

Powered by devMail.Net (Free Version) - The Most Powerful .Net Email Component.
devMail.Net is not the sender of this email nor responsible for the content.