

PJ

✓
[Redacted]
From: Peter Jefcoate
Sent: 09 July 2012 14:28
To: Planning
Subject: FW: 10 Park Street, Old Hatfield, HATFIELD- N6/2012/1106/LB

Admin,

Please register as a consultation response from BEAMS for the above application

Many thanks

10 July 2012

Peter

From: Robin Uff [Redacted]
Sent: 07 July 2012 00:15
To: Peter Jefcoate; Robin Uff
Subject: 10 Park Street, Old Hatfield, HATFIELD- N6/2012/1106/LB

Grade II listed building; conservation area.

Hi Peter-

I visited the site a couple of weeks ago & spoke briefly with the applicant. The proposed **re-pointing of the front street elevation** in lime-based mortar is, of course, to be welcomed & encouraged. I suggested that while these enhancing works are to be carried out it would be an opportune time to re-introduce cast iron rwgs also.

As with all re-pointing, & seeking to achieve a sympathetic, high conservation standard of work, so much depends on the skill of the craftsman carrying out the re-pointing, so, I suggest a condition or directive to request that a sample area be prepared for inspection & agreement & to act as a reference for all other pointing finish.

Cheers *Rob*

Click [here](#) to report this email as spam.