

Sukaina Devraj

MP MS ✓

From: DataSpace Consult [system@dataspaceconsult.co.uk]
Sent: 30 January 2013 14:49
To: Planning
Subject: Comments Added: Eisai Europe Limited European Knowledge Centre, Mosquito Way, Hatfield

Dear Development

Please be aware that comments have been added to the following application:

Application Details:

Application ID: S6/2012/2641/FP Mr M Peacock Application Owner: Welwyn & Hatfield Borough Council (Development Management Officer)

Applicant: AECOM

Location: Eisai Europe Limited European Knowledge Centre, Mosquito Way, Hatfield Deadline

Date: 08/02/2013 00:00:00

Description: Erection of storage warehouse Comment Added:

Commented By: gerry.brophy@herts.pnn.police.uk

Comment: Speaking from a crime prevention perspective, the only issue I would have with this application is whether the possibility of an arson attack has been fully considered. Large amounts of combustible materials will be present on site and some of this will inevitably end up outside the immediate structure of the building. Fire regulations will cover the interior of the building, but I would like to see a secure area for the storage of any waste material prior to its removal from site. This area should have some form of access control. Gerry Brophy, Principal Crime Prevention Design Officer, Hertfordshire Constabulary.

Please click the following link to review these comments:

<http://www.consultlive.co.uk/index.aspx?appID=10631>

Any reply to this email will be logged against the consultation.

If you have problems with this link, please email the Consult-Live help team - helpdesk@resolutiondm.com quoting reference: EM004

Powered by DataSpace Consult Live www.consultlive.co.uk

Powered by devMail.Net (Free Version) - The Most Powerful .Net Email Component.
devMail.Net is not the sender of this email nor responsible for the content.