


From: DataSpace Consult [system@dataspaceconsult.co.uk]
Sent: 13 November 2014 15:03
To: Planning
Subject: Comments Added: Land off Comet Way Hatfield



Dear Development

Please be aware that comments have been added to the following application:

Application Details:

Application ID: S6/2014/1443/MA Duty Officer Application Owner: Welwyn & Hatfield Borough Council (Development Management Officer)
Applicant: Absolute Interiors
Location: Land off Comet Way Hatfield
Deadline Date: 13/10/2014 00:00:00
Description: Erection of new public house and associated works Comment Added:

Commented By: e.health@welhat.gov.uk

Comment: Response in relation to the noise management report and ventilation consultants information:

1. Env Health haven't specifically specified that noise levels for mechanical services 5dB(A) and I am unsure where the acoustic consultant has attained this figure from. I want a factor of 10dB(A) below background applied for all noise sources including mechanical noise, people in the garden, smoking shelter and noise breakout.
2. We would like the acoustic to carry out and noise assessment which combines all the noise sources identified rather than being modelled separately.
3. Tonal effect of plant has not been included although a BS4142 has been referred to.
4. Please can the acoustic consultant explain what premises was modelled for the people noise in the garden. The description of that pub should include: size of pub, numbers of people in the garden, type of day/day of week, client type and method of assessment
5. The position of the smoking shelter is not appropriate and should be moved to the opposite end of the beer garden (also required via licensing and for the installation of a gate).
6. The position of the entrance and exit doors to the beer garden faces directly towards the hotel. This just be moved to a position 90o away from the hotel.
7. Deliveries have not been considered as a noise source
8. Odour risk assessment has not been undertaken as requested

Please click the following link to review these comments:

<http://www.consultlive.co.uk/index.aspx?appID=13112>

Any reply to this email will be logged against the consultation.

If you have problems with this link, please email the Consult-Live help team - helpdesk@resolutiondm.com quoting reference: EM004

Powered by DataSpace Consult Live www.consultlive.co.uk

Powered by devMail.Net (Free Version) - The Most Powerful .Net Email Component.
devMail.Net is not the sender of this email nor responsible for the content.