

1152/2A

09 November 2017

Manning Elliot Partnership
Suite 1 Manelli House,
4 Cowper Road,
Penrith,
Cumbria
CA11 9BN

For the attention of George Scott

Dear George,

RE:- ONE HATFIELD HOSPITAL – ACOUSTIC REPORT

Please find attached the Acoustic Survey undertaken at ONE Hatfield Hospital.

Please be advised that following all final regulation, validation and commissioning of the Mechanical plant the external noise level has been remeasured and the noise emitted by the combined operation of all external building services plant hereby permitted does not exceed 10db below background noise level at any time when the plant is operating.


Measurements were taken 4m away from the nearest residential property.

The measurement position was 27m from the nearest plant, whereas the nearest residential receiver's window was 33m from the nearest plant.

Subjectively, the plant was noted as inaudible at the nearest residential property.

If you have any queries please contact me,

Yours Sincerely,
WALMSLEY ASSOCIATES


BEN CURRAN
