Stephen Anyanwu

RAR. (MP

From:

Fiona Lai [Fiona.Lai@hertfordshire.gov.uk]

Sent:

22 July 2015 15:16

To:

Mark Peacock; Planning

Subject:

S6/2015/0524/FP - Bule Moon Paddock

Hi Mark,

PLANNING
DEPARTMENT

2 2 JUL 2015

RECEIVED

Please find enclosed attachment with our comment.

Regards, Fiona

Fiona Lai

Environmental Resource Planning

Hertfordshire County Council Ground Floor County Hall Postal Point: CHN215 Hertford

Hertfordshire

SG13 8DN

Tel: 01992 556295 Comnet/Internal 26295

Email: fiona.lai@hertfordshire.gov.uk

****Disclaimer****

The information in this message should be regarded as confidential and is intended for the addressee only unless explicitly stated. If you have received this message in error it must be deleted and the sender notified. The views expressed in this message are personal and not necessarily those of Hertfordshire County Council unless explicitly stated. Please be aware that emails sent to or received from Hertfordshire County Council may be intercepted and read by the council. Interception will only occur to ensure compliance with council policies or procedures or regulatory obligations, to prevent or deter crime, or for the

S620150524FP - Blue Moon Paddo...

purposes of essential maintenance or support of the email system.

Environment Director & Chief Executive: John Wood



Mark Peacock
Welwyn Hatfield Borough Council

Council Offices
The Campus
Welwyn Garden City

PLANNING DEPARTMENT

2 2 JUL 2015

RECEIVED

Post Point CHN 215
Hertfordshire County Council
County Hall, Pegs Lane
HERTFORD SG13 8DN

Contact Sophie Williamson

Tel 01992 556492

Email FRMConsultations@hertfordshire.gov.uk

Date 22 July 2015

RE: S6/2015/0524/FP - Blue Moon Paddock, Woodfield Lane, Brookmans Park

Dear Mark

AL8 6AE

In response to the revised FRA carried out by ARK Environmental Consultancy Ltd dated 30 June 2015, we are now in a position to remove our objection on flood risk grounds and have no in principle objections to the development as we feel the development is capable of being drained. However we still have some concerns which we feel would be appropriate to deal with through an appropriate planning condition.

Our concerns relate to the following:

- Confirmation that infiltration is feasible to determine the detailed design of the drainage scheme
- Proposed location of the swale is situated on ground that lies above the proposed property
- No information on the possible risk of overland flows flooding the proposed property and providing appropriate mitigation by raising finished floor levels, external airbricks etc.

We therefore recommend the following condition to the LPA should planning permission be granted:

LLFA Position

The proposed development will be acceptable if a planning condition is included requiring the following drainage details.

Condition

No development shall take place until a revised surface water drainage scheme for the site, based on sustainable drainage principles and an assessment of the hydrological and hydro geological context of the development, has been submitted to and approved in writing by the local planning authority. The drainage strategy should demonstrate the surface water run-off generated up to and including the <insert return period e.g. 100 years> critical storm will not exceed the run-off from the undeveloped site following the corresponding rainfall event. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

The scheme shall also include:

- Confirmation that infiltration is feasible to determine the detailed design of the drainage scheme by carrying out infiltration tests in accordance with BRE Digest 365
- Revise the proposed location of the swale as it is currently situated on ground that lies above the proposed property which will not be able to drain the roof drainage via gravity and also be at risk of flooding the property should it over top.
- Assess the possible risk of overland flows flooding the proposed property and providing appropriate mitigation by raising finished floor levels, external airbricks etc.

Reason

To prevent the increased risk of flooding, both on and off site. We ask to be consulted on the details submitted for approval to your Authority to discharge this condition and on any subsequent amendments/alterations.

Yours sincerely,

Sophie Williamson

Hertfordshire County Council

01992 556492 FRMConsultations@hertfordshire.gov.uk