

# Comment for planning application 6/2021/2791/HOUSE

<b>Application Number</b>	<input type="text" value="6/2021/2791/HOUSE"/>
<b>Location</b>	<input type="text" value="28 Theobalds Road Cuffley Potters Bar EN6 4HQ"/>
<b>Proposal</b>	<input type="text" value="Conversion of loft to habitable space including roof alterations, the addition of side dormers and the erection of a part first floor and part single storey side and rear extension"/>
<b>Case Officer</b>	<input type="text" value="Ms Emily Stainer"/>
<b>Organisation</b>	<input type="text"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text" value="neighbour"/>
<b>Comments</b>	<input type="text" value="Having taken some independent advice we also believe there is an issue with the dormer design, namely, the distance from the rear wall to the dormer should be a minimum of 1350mm, and the windows should be high-level slotted deign with obscure glass."/>
<b>Received Date</b>	<input type="text" value="04/11/2021 12:46:02"/>
<b>Attachments</b>	