



*Ack*

*JP*

# Memo.

PLANNING  
DEPARTMENT

09 JAN 2012

RECEIVED

**Date:** 6<sup>th</sup> January 2012

**To:** Planning

**Cc:** -

**From:** Miriam Hill

**Subject:** S6/2011/2782/FP – 97 Bramble Road, Hatfield

**Erection of single storey rear extension, first floor side and single storey front extensions and loft conversion with skylight windows to front, side and rear elevations**

---

I have reviewed the proposal for the above site and refer to drawing number BR101-10 and BR101-10A.

## Arboriculturally

There is one tree within the front garden which is young and small. If this tree is to be kept through the construction period, the applicant should bear in mind that excavation or compaction of the soil close to trees can damage the roots and/or soil and be potentially harmful. Care must be taken whilst working around them, guidance can be sort from BS5837:2005 Trees in Relation to Construction or from a arboricultural or landscape professional.

## Summary

Overall I have no objections to this application. I hope that these comments are clear and that if you need anything further then please contact me.