



FAO: Planning Department,
Welwyn Hatfield Borough Council

Ref: 6/2018/2665/COND
Date: 20/11/2018

HISTORIC BUILDINGS AND CONSERVATION ADVICE

Dear Sir / Madam,

RE: Ramada Hatfield, St Albans Road West, Hatfield, AL10 9RH

The application includes the submission of details pursuant to condition 4 (Part A - roof lantern, Part D - door openings and frames, Part E - window openings and frames and Part H - Rooflights to kitchen) on listed building consent 6/2017/2746/LB, dated 15/02/2018.

The details submitted are sufficient to discharge condition 4. The window sample has previously been inspected on site and deemed to be acceptable. However, there is a concern with regards to Part H as the height of the flagpole on the roof lantern appears to be shorter than that shown in elevation drawings submitted with the original listed building consent (e.g drawing no. COMET-STL-01-XX-DR-A-XXXX-02006 Rev. P45). The height of the flagpole should match the original.

Yours sincerely

Maria Kitts BA (Hons) MA PGCert
Senior Historic Buildings Consultant
Place Services

Note: This letter is advisory and should only be considered as the opinion formed by specialist staff in relation to this particular matter

