

TABLE P3  
ANNUAL PROBABLE SUNLIGHT HOURS (APSH)  
SURROUNDING BUILDINGS

PROPERTY			WINDOW									
			ANNUAL SUNLIGHT (%APSH)					WINTER SUNLIGHT (% APSH IN WINTER)				
			Submitted scheme			Amended scheme		Submitted scheme			Amended scheme	
Room ref.	Window ref.	Room use	Existing (%)	Proposed (%)	*Factor of former value	Proposed (%)	*Factor of former value	Existing (%)	Proposed (%)	*Factor of former value	Proposed (%)	*Factor of former value
<b>PARKHOUSE COURT</b>												
<b>1st Floor</b>												
R1	W1	LKD	59	18	0.40	40	N/A	22	5	N/A	11	N/A
R2	W2	BEDROOM	58	20	0.45	36	N/A	22	0	0.00	8	N/A
R3	W3	BEDROOM	66	17	0.40	44	N/A	24	1	0.06	9	N/A
R4	W4	LKD	52	16	0.42	36	N/A	21	4	0.24	11	N/A
R5	W5	LKD	45	13	0.33	28	N/A	13	1	0.08	4	0.31
R6	W6	BEDROOM	60	19	0.43	41	N/A	21	2	0.13	9	N/A
R7	W7	BEDROOM	51	13	0.43	34	N/A	16	1	0.14	7	N/A
R8	W8	BEDROOM	50	13	0.43	34	N/A	16	1	0.17	7	N/A
R9	W9	LKD	41	9	0.30	23	0.56	15	1	0.10	6	N/A
<b>2nd Floor</b>												
R1	W1	LKD	62	23	0.49	46	N/A	25	6	N/A	14	N/A
R2	W2	BEDROOM	58	25	N/A	44	N/A	22	1	0.07	13	N/A
R3	W3	BEDROOM	64	21	0.49	51	N/A	24	2	0.13	15	N/A
R4	W4	LKD	55	24	0.60	43	N/A	24	6	N/A	15	N/A
R5	W5	LKD	48	19	0.46	33	N/A	16	3	0.20	7	N/A
R6	W6	BEDROOM	60	24	0.55	44	N/A	21	5	N/A	12	N/A
R7	W7	BEDROOM	48	15	0.50	35	N/A	16	2	0.29	9	N/A
R8	W8	BEDROOM	47	16	0.53	35	N/A	16	2	0.33	10	N/A
R9	W9	LKD	41	13	0.43	30	N/A	15	3	0.30	8	N/A
<b>3rd Floor</b>												
R1	W1	LKD	58	29	N/A	49	N/A	25	10	N/A	18	N/A

\*NOTES: 'Factor of former value' = Proposed/Existing. A factor >1 indicates an increase in sunlight. An APSH > 25%/5% satisfies BRE criteria and ratio is N/A. Total annual sunlight (100% APSH) in London is 1486 hours.

TABLE P3  
 ANNUAL PROBABLE SUNLIGHT HOURS (APSH)  
 SURROUNDING BUILDINGS

PROPERTY			WINDOW									
			ANNUAL SUNLIGHT (%APSH)					WINTER SUNLIGHT (% APSH IN WINTER)				
			Submitted scheme			Amended scheme		Submitted scheme			Amended scheme	
Room ref.	Window ref.	Room use	Existing (%)	Proposed (%)	*Factor of former value	Proposed (%)	*Factor of former value	Existing (%)	Proposed (%)	*Factor of former value	Proposed (%)	*Factor of former value
R2	W2	BEDROOM	53	19	0.54	43	N/A	22	3	0.20	15	N/A
R3	W3	BEDROOM	47	16	0.50	39	N/A	20	4	0.27	15	N/A
R4	W4	LKD	52	27	N/A	45	N/A	22	7	N/A	16	N/A
R5	W5	LKD	48	27	N/A	38	N/A	16	6	N/A	10	N/A
R6	W6	BEDROOM	47	16	0.52	38	N/A	20	5	N/A	16	N/A
R7	W7	BEDROOM	33	10	0.45	25	N/A	12	2	0.29	9	N/A
R8	W8	BEDROOM	37	16	0.62	30	N/A	13	3	0.50	10	N/A
R9	W9	LKD	37	20	0.67	30	N/A	13	5	N/A	10	N/A

\*NOTES: 'Factor of former value' = Proposed/Existing. A factor >1 indicates an increase in sunlight. An APSH > 25%/5% satisfies BRE criteria and ratio is N/A. Total annual sunlight (100% APSH) in London is 1486 hours.