

Acoustic Consultancy Report

79581/3/3/3

Acoustic Commissioning Report

Report Prepared For

Walmsley Associates
Hatfield One Healthcare
09 October 2017

Report Author

Sam Shapley BSc (Hons)

Telephone

0118 918 6460

Facsimile

0118 918 6480

enquiries@lcpacoustics.co.uk
www.lcpacoustics.co.uk

LCP

Riverside House
3 Winnersh Fields
Gazelle Close
Winnersh
Wokingham
RG41 5QS

A division of CAICE
Acoustic Air Movement Ltd.

Company Registration Number
2790667

VAT Registration Number
GB614683632

Contents

i)	Executive Summary	3
ii)	Document History	3
1	Introduction	4
2	Testing Programme	4
2.1	Calibration	4
2.2	Site Description	4
2.3	Local Noise Climate	5
2.4	Weather.....	5
3	Residential Design Criteria	5
3.1	BS4142:2014	5
3.2	BREEAM 2014 - Pol 05 Criteria.....	6
4	Current Design	7
5	Results	7
5.1	Daytime	7
5.2	Night-time.....	8
6	Conclusion	8
	Appendix A: Site Plan.....	9
	Appendix B: Measurement Data	10
	Appendix C: Calculations	11
	Appendix D: Glossary.....	12

i) Executive Summary

Acoustic commissioning test has been performed at ONE Hatfield Hospital.

External testing of plant was carried out in accordance with the procedure outlined in BS4142:2014.

The noise levels from the plant are below the criteria stated in SRL's Technical Report C/41864A/T01/JRHS criteria of 49dB(A) during the day and 45dB(A) during the night at the nearest receiver.

The BS4142 assessment undertaken concludes that there is indication of low impact.

This report concludes that the design criteria and BREEAM POL 05 requirements has been achieved and 1 BREEAM credit can be awarded.

ii) Document History

Issue	Date	Issue Details	Issued By	Checked By
1	29/09/2017	Initial Issue	SS	MB
2	03/10/2017	Revised wording	SS	-
3	09/10/2017	Revised wording	SS	-

1 Introduction

The development at ONE Hatfield Hospital has reached Practical Completion.

Acoustic commissioning testing has been carried out to confirm the following noise aspect of the design has been achieved:

Commissioned Aspect

External Airborne noise levels from mechanical plant.

This report details all measurement results and data obtained during the testing period, and sets out all findings following comparison of the obtained data with the project design criteria.

2 Testing Programme

The testing was carried out from 23:00 26th September 2017 to 00:15 27th September 2017.

Testing was carried out by Sam Shapley of LCP.

Neil Mercer from The James Mercer Group was in attendance to operate the plant.

All plant had been balanced and commissioned prior to testing.

All external noise measurements have been made in accordance with the method outlined in BS4142:2014.

2.1 Calibration

The measurement equipment (as detailed at the end of Appendix B) was calibrated prior to and after obtaining measurements.

The recorded calibration gain adjustment levels were as follows:

Table 1: Calibration gain adjustment levels (114dB at 1 kHz), dB re 2x10⁻⁵ Pa

Location	Before	After
MP1	2.31	2.46
MP2	0.15	0.22

2.2 Site Description

The site layout, together with the measurement positions, is shown in the drawing contained within Appendix A.

The nearest receiver with direct line of sight to the plant area is 70m to the north east of the site. This is shown in the site plan in Appendix A.

2.3 Local Noise Climate

The predominant local noise source was road traffic noise on the A1(M).

2.4 Weather

The weather conditions monitored during the survey are shown in the following table.

Table 2: Weather Conditions at Measurement Location

Weather	Value
Average Wind Speed	2m/s
Wind Direction	East
Cloud Cover	100%
Temperature	13°C
Precipitation	None

3 Residential Design Criteria

The design criteria have been obtained from SRL Technical Report C/41864A/T01/JRHS, and are summarised below.

Airborne noise from all externally located building services shall be controlled to the following levels at the respective noise sensitive receptors:

Table 3: External design rating levels, dB re 2×10^{-5} Pa

Receiver premises	Approximate distance (m)	Design Level Day $L_{A,T}$	Design Level Night $L_{A,T}$
17 Manor Road	33	49	45

3.1 BS4142:2014

BS4142:2014 states that the significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs.

Table 4: BS4142 assessment based upon rating level

Difference between background noise and rating levels	Assessment
+ 10 dB	Indication of a significant adverse impact
+ 5 dB	Indication of an adverse impact
0 dB	Indication of low impact

Certain acoustic features can increase the significance of impact. The specific sound level should be corrected if a tone, impulse or other acoustic feature is expected to be present.

Table 5: Corrections for acoustic features, subjective method

Acoustic Feature	Correction, dB		
	Just Perceptible	Clearly Perceptible	Highly Perceptible
Tonality	2	4	6
Impulsivity	3	6	9
Other Characteristics	3		
Intermittency	3		

Typically the acoustic feature correction would not be expected to exceed 10dB.

Where the level of uncertainty could affect the conclusion, take reasonably practicable steps to reduce the level of uncertainty.

3.2 BREEAM 2014 - Pol 05 Criteria

BREEAM Pol 05 criterion is aimed to reduce the likelihood of noise arising from fixed installations on the new development affecting nearby noise-sensitive buildings.

Table 6: BREEAM Pol 5 criteria

Credit Available	Criteria	Testing Required
One Credit	Where there are, or will be, no noise-sensitive areas or buildings within 800m radius of the assessed development.	
	<p>Where the building does have noise-sensitive areas or buildings within 800m radius of the development a credit can be awarded for:</p> <ul style="list-style-type: none"> a) Where a noise impact assessment in compliance with BS7445 has been carried out and the following noise levels measured/determined: <ul style="list-style-type: none"> i) Existing background noise levels at the nearest or most exposed noise-sensitive development or at a location where background conditions can be argued to be similar ii) The rating noise level resulting from the new noise source b) The noise impact assessment must be carried out by a suitable qualified acoustic consultant holding a recognised acoustic qualification and membership of an appropriate professional body. c) The noise level from the proposed site/building, as measured in the locality of the nearest or most exposed noise-sensitive development, is a difference no greater than +5dB during the day (07:00 to 23:00) and +3dB at night (23:00 to 07:00) compared to the background noise level. d) Where the noise source(s) from the proposed site/building is greater than the levels described in the criterion, measures have been installed to attenuate the noise at its source to a level where it will comply 	Yes

4 Current Design

The plant is located on the roof of the hospital, a 2.5m high acoustic screen surrounds the plant area. The plant includes seven AHUs.

The four AHUs supplying the Theatre & Recovery rooms will operate at a setback speed (70%) during night time hours (18:00 - 08:00). The AHU serving the Ambulatory Care and Consulting rooms will operate during day time hours (08:00 - 18:00). The two AHUs serving the Wards and Spinal Recovery rooms will operate over a 24-hour period.

5 Results

A BS4142 assessment has been carried out using the levels measured from the acoustic commissioning. The measured sound pressure levels are shown within Appendix B.

Measurements were taken 4m away from the nearest residential property.

The measurement position was 30m from the nearest plant. 1m from the nearest residential receiver's window was 33m from the nearest plant.

Calculations can be found in Appendix C.

5.1 Daytime

Table 7: BS4142 assessment, dB re 2×10^{-5} Pa

Results	Result dB(A)	Comments
Measured Ambient sound level L_{Aeq} (Plant on)	52.5	Plant is barely detectable, heavily masked by road traffic noise.
Residual sound level L_{Aeq} (Plant off)	49.1	
Background sound level L_{A90} (Plant off)	45.5	Road traffic noise was the only noise source detected.
Specific sound level calculated by correcting the ambient sound level to remove the contribution of the residual sound level L_{Aeq}	49.8	Calculations can be found in Appendix C
Distance Correction of 3m	$49.8 - 0.8 = 49.0$	Calculations can be found in Appendix C
Acoustic feature correction	0	No tonality, impulsivity or intermittency characteristics were detected.
Rating level	49.0	
Daytime background sound level criteria	49.0	
Excess of rating over background sound level criteria	+/- 0	
Assessment	Indication of low impact	

5.2 Night-time

Results	Result dB(A)	Comments
Measured Ambient sound level L_{Aeq} (Plant on)	50.5	Plant is barely detectable, heavily masked by road traffic noise
Residual sound level L_{Aeq} (Plant off)	49.1	
Background sound level L_{A90} (Plant off)	45.5	Road traffic noise was the only noise source detected
Specific sound level calculated by correcting the ambient sound level to remove the contribution of the residual sound level L_{Aeq}	44.9	Calculations can be found in Appendix C
Distance Correction of 3 meters	$44.9 - 0.8 = 44.1$	Calculations can be found in Appendix C
Acoustic feature correction	0	No tonality, impulsivity or intermittency characteristics were detected
Rating level	44.1	
Night-time background sound level criteria	45.0	
Excess of rating over background sound level criteria	-0.9	
Assessment	Indication of low impact	

6 Conclusion

Acoustic commissioning testing has been undertaken at ONE Hatfield Hospital. Calculations have been carried out to determine the noise levels at the nearest receiver premises.

The noise levels from the plant are below or equal to the criteria stated in SRL's Technical Report C/41864A/T01/JRHS of 49dB(A) during the day and 45dB(A) during the night at the nearest receiver.

The BS4142 assessment undertaken concludes that there is indication of low impact.

This report concludes that the design criteria and BREEAM POL 05 requirements has been achieved and 1 BREEAM credit can be awarded.

Appendix A: Site Plan



Approximate measurement position (Latitude & Longitude) 51°46'17.59" N 0°14'10.33" W



Appendix B: Measurement Data

L_{Aeq}

No	Date & time	Elapsed time	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	L _{Aeq}	Plant State
1	26/09/2017 23:14:26	00:15:00	61.6	51.3	48.1	48.6	51.4	45.8	40.5	34.7	53.9	Daytime Mode
2	26/09/2017 23:29:26	00:15:00	61	50.3	48.1	47.7	50.5	42.9	33	26.1	52.5	Daytime Mode
3	26/09/2017 23:45:10	00:15:00	61.1	49.4	46.1	46.1	48.3	41.4	32.2	24.2	50.5	Night-time Mode
4	27/09/2017 00:01:07	00:15:00	60	47.6	43	44.1	47.2	39.4	29	23.1	49.1	All Plant Off

L_{A90}

No	Date & time	Elapsed time	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	L _{A90}	Plant State
1	26/09/2017 23:14:26	00:15:00	55.7	45.7	42.1	44	47.2	38.9	24.6	15.7	49.1	Daytime Mode
2	26/09/2017 23:29:26	00:15:00	54.9	45.6	42.1	44.1	47.1	39.1	25.3	16.3	49.1	Daytime Mode
3	26/09/2017 23:45:10	00:15:00	55.2	44	40.5	42	44.7	37.3	24.7	16.2	47.0	Night-time Mode
4	27/09/2017 00:01:07	00:15:00	53.5	42.5	39	40.2	43.4	35.5	21.5	13.6	45.5	All Plant Off

Sound pressure level measurements were obtained using the following instrumentation complying with the Class 1 specification of BS EN 61672:2003

- Svantek 959 Sound Level Meter S/N: 11259
- Svantek pre-amplifier SV12L S/N: 11484 with GRAS microphone capsule 40AE S/N: 82239
- Svantek 959 Sound Level Meter S/N: 11207
- Svantek pre-amplifier SV12L S/N: 49860 with GRAS microphone capsule 40AE S/N: 215511

Calibration checks were made prior to and after completion of measurements using a Bruel & Kjaer 4231 calibrator, S/N: 10890 complying with Class 1 specification of BS EN 60942:2003, calibration level 114.0 dB @ 1.0 kHz. All acoustic instrumentation carried current manufacturer's certificates of conformance.



Appendix C: Calculations

Daytime specific sound calculation

Subtract		Log
1	52.5	177828
2	49.1	81283
	49.8	96545

Night-time specific sound calculation

Subtract		Log
1	50.5	112202
2	49.1	81283
	44.9	30919

Distance correction Daytime

L1 to L2 point source				
L1	r1	r2	L2	Loss
49.8	30.0	33.0	49.0	0.8

Distance correction Night-time

L1 to L2 point source				
L1	r1	r2	L2	Loss
44.9	30.0	33.0	44.1	0.8

Appendix D: Glossary

The list below details the major acoustical terms and descriptors, with brief definitions:

'A' Weighting

Weighting applied to the level in each stated octave band by a specified amount, in order to better represent the response of the human ear. The letter 'A' will follow a descriptor, indicating the value has been 'A' weighted. An 'A' weighted noise level may also be written as dB(A).

Absorption Class

In order to categorise the absorptive effects of different elements (such as ceiling tiles), classes from A to E were derived, as per BS EN ISO 11654:1997. A class 'A' absorber would be very acoustically absorptive, a Class 'E' absorber would be less absorptive and more reflective. A product that is highly reflective may not be classified.

Absorption Coefficient (α)

A value usually between 0 and 1 assigned to a material to indicate how acoustically absorptive it is. 0 indicates a material is entirely reflective (and therefore not absorptive), and 1 indicates a material is entirely absorptive (and therefore not reflective). Absorption coefficients are usually given for each octave band between 125Hz and 4kHz, or as an overall 'practical' coefficient.

Airborne Noise

Noise transmitted through air.

dB or Decibel

Literally meaning 'a tenth of a bel', the bel being a unit devised by the Bell Laboratory and named after Alexander Graham Bell. A logarithmically based descriptor to compare a level to a reference level. Decibel arithmetic is not linear, due to the logarithmic base. For example:

$$30 \text{ dB} + 30 \text{ dB} \neq 60 \text{ dB}$$

$$30 \text{ dB} + 30 \text{ dB} = 33 \text{ dB}$$

$D_{nT} + C_{tr}$

The weighted, normalised difference in airborne noise levels measured in a source room (L1) and a receive room (L2) due to a separating partition.

D	Is simply $L1 - L2$.
---	-----------------------

D_{nT}	Is the normalisation of the measured level difference to the expected (in comparison to the measured) reverberation time in the receiving room.
----------	---

D_{nTw}	Is the weighted and normalised level difference. This value is the result of applying a known octave band weighting curve to the measured result.
C_{tr}	Is a correction factor applied to the D_{nTw} to account for the known effects of particular types of noise, such as loud stereo music or traffic noise.
Frequency (Hz)	
Measured in Hertz (after Heinrich Hertz), and represents the number of cycles per second of a sound or tone.	
Impact Noise	
Re-radiated noise as a result of impact(s) on a solid medium, such as footfalls on floors.	
Insertion Loss, dB	
The amount of sound reduction offered by an attenuator or louvre once placed in the path of a noise level.	
$L_{A90, T}$	
The 'A' weighted noise level exceeded for 90% of the time period T, described or measured. The '90' can be substituted for any value between 1 and 99 to indicate the noise level exceeded for the corresponding percentage of time described or measured.	
$L_{Aeq, T}$	
The 'A' weighted 'equivalent' noise level, or the average noise level over the time period T, described or measured.	
L_{Amax}	
The 'A' weighted maximum measured noise level. Can be measured with a 'slow' (1 sec) or 'fast' (0.125 sec) time weighting.	
L_{Amin}	
The 'A' weighted minimum measured noise level.	
L'_{nTw}	
The weighted, normalised impact sound pressure level measured in a receive room below a source room.	
L	Is the spatially averaged impact sound pressure level

	measured in a receive room.
L'_{nT}	Is the normalisation of the measured impact sound pressure level to the expected (in comparison to the measured) reverberation time in the receiving room.
L'_{nTw}	Is the weighted and normalised impact sound pressure level. This value is the result of applying a known octave band weighting curve to the measured result.

NR

Noise Rating (NR) level. A frequency dependent system of noise level curves developed by the International Organisation for Standardisation (ISO). NR is used to categorise and determine the acceptable indoor environment in terms of hearing preservation, speech communication and annoyance in any given application as a single figure level. The US predominantly uses the Noise Criterion (NC) system.

Octave

The interval between a frequency in Hz (f) and either half or double that frequency (0.5f or 2f).

Pa

Pascals, the SI unit to describe pressure, after physicist Blaise Pascal.

Reverberation Time, T_{mf} , RT60, RT30 or RT20

The time taken in seconds for a sound to diminish within a room by 1,000 times its original level, corresponding to a drop in sound pressure of 60 dB. When taking field measurements and where background noise levels are high, the units RT20 or RT30 are used (measuring drops of 20 or 30 dB respectively). Sometimes given as a mid-frequency reverberation time, T_{mf} which is the average of reverberation time values at 500Hz, 1kHz and 2kHz.

R_w

The sound reduction value(s) of a constructional element such as a door, as measured in a laboratory, with a known octave band weighting curve applied to the result.

Sound Power Level

A noise level obtained by calculation from measurement data, given at the face of an item of plant or machinery. Referenced to 10^{-12} W or 1pW.

Sound Pressure Level



A noise level measured or given at a distance from a source or a number of sources. Referenced to 2×10^{-5} Pa.

W

Watts, the SI unit to describe power, after engineer James Watt.