

I refer to the above mentioned application and am writing in respect of planning obligations sought by the County Council towards fire hydrants to minimise the impact of development on Hertfordshire County Council Services for the local community. Please note that this does not cover all Hertfordshire Property Services and we may contact you under combined separate cover regarding a specific and demonstrated need for early years provision, primary education, secondary education, library, youth, waste and adult care services.

Based on the information provided to date we would seek the provision of fire hydrant(s), as set out within HCC's Planning Obligations Toolkit.

All developments must be adequately served by fire hydrants in the event of fire. The County Council as the Statutory Fire Authority has a duty to ensure fire fighting facilities are provided on new developments. HCC therefore seek the provision of hydrants required to serve the proposed buildings by the developer through standard clauses set out in a Section 106 legal agreement or unilateral undertaking.

Buildings fitted with fire mains must have a suitable hydrant provided and sited within 18m of the hard-standing facility provided for the fire service pumping appliance.

The requirements for fire hydrant provision are set out with the Toolkit at paragraph 12.33 and 12.34 (page 22). In practice, the number and location of hydrants is determined at the time the water services for the development are planned in detail and the layout of the development is known, which is usually after planning permission is granted. If, at the water scheme design stage, adequate hydrants are already available no extra hydrants will be needed.

Section 106 planning obligation clauses can be provided on request.

Justification

Fire hydrant provision based on the approach set out within the Planning Obligations Guidance - Toolkit for Hertfordshire (Hertfordshire County Council's requirements) document, which was approved by Hertfordshire County Council's Cabinet Panel on 21 January 2008 and is available via the following link: www.hertsdirect.org/planningobligationstoolkit

The County Council seeks fire hydrant provisions for public adoptable fire hydrants and not private fire hydrants. Such hydrants are generally not within the building site and are not covered by Part B5 of the Building Regulations 2010 as supported by Secretary of State Guidance "Approved Document B".

In respect of Regulation 122 of the CIL Regulations 2010 the planning obligations sought from this proposal are:

(i) Necessary to make the development acceptable in planning terms.

Recognition that contributions should be made to mitigate the impact of development are set out in planning related policy documents. The NPPF states "Local planning authorities should consider whether otherwise unacceptable development could be made acceptable through the use of conditions or planning obligations. Conditions cannot be used cover the payment of financial contributions to mitigate the impact of a development (Circular 11/95: Use of conditions in planning permission, paragraph 83).

All developments must be adequately served by fire hydrants in the event of fire. The County Council as the Statutory Fire Authority has a duty to ensure fire fighting facilities are provided on new developments. The requirements for fire hydrant provision are set out with the Toolkit at paragraph 12.33 and 12.34 (page 22).

(ii) Directly related to the development;

Only those fire hydrants required to provide the necessary water supplies for fire fighting purposes to serve the proposed development are sought to be provided by the developer. The location and number of fire hydrants sought will be directly linked to the water scheme designed for this proposal.

(iii) Fairly and reasonable related in scale and kind to the development.

Only those fire hydrants required to provide the necessary water supplies for fire fighting purposes to serve the proposed development are sought to be provided by the developer. The location and number of fire hydrants sought will be directly linked to the water scheme designed for this proposal.

I would be grateful if you would keep me informed about the progress of this application so that either instructions for a planning obligation can be given promptly to our legal team if your authority is minded to grant consent or, in the event of an appeal, information can be submitted in support of the requested provision.

I trust the above is of assistance if you require any further information please contact the Development Services team.

Kind regards