

Consultee Comment for planning application 6/2022/1444/FULL

Application Number	6/2022/1444/FULL
Location	12 Harpsfield Broadway Hatfield AL10 9TF
Proposal	Erection of part two, part three storey rear extension with mansard roof and conversion to 8 flats comprising 6 x 2-bed and 2 x studio
Case Officer	Ms Elizabeth Mugova
Organisation	WHBC - Client Services
Name	Lorraine Davis
Address	Client Services The Campus Welwyn Garden City AL8 6AE
Type of Comment	ConditionalResponse
Type	
Comments	25/07/2022 - Lorraine Davis The flats would require 1 x 1100l + 1 x 240l refuse bins, 1 x Mini recycling Centre and 1 x 140l food waste bin. The bins need to be kept separated from the commercial waste services. I would suggest an enclosed bin store area with a coded lock for residents bins to avoid flytipping and cross use by commercial premises and vice versa. Doors to be double doors opening outwards with a dropped kerb to freighter and a flat path from store to freighter max drag distance of 15m. Cost of receptacles ?1439.16
Received Date	25/07/2022 10:17:34
Attachments	