

Consultee Comment for planning application 6/2022/1106/FULL

Application Number	<input type="text" value="6/2022/1106/FULL"/>
Location	<input type="text" value="1 Longcroft Green Welwyn Garden City AL8 6EP"/>
Proposal	<input type="text" value="Erection of 1 x detached 4 bedroom dwelling and detached 3 and a half storey building accommodating 6 no flats (4 x 2 bedroom and 2 x 3 bedroom flats), car parking, refuse and recycling bins enclosure, secure cycle storage, turning heads and use of the existing vehicular access following the demolition and removal of a pair of semi-detached dwellings."/>
Case Officer	<input type="text" value="Ms Louise Sahlke"/>
Organisation	<input type="text" value="WHBC - Client Services"/>
Name	<input type="text" value="Lorraine Davis"/>
Address	<input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="08/04/2024 Lorraine Davis - No additional comments on refuse requirements. Refuse tracking diagram noted and acceptable. Please ensure the refuse store has double doors opening outwards which can be secured in the open position for servicing, coded lock, a minimum 2m wide tarmac path from store to freighter with dropped kerb , max drag distance 15m."/>
Received Date	<input type="text" value="08/04/2024 17:18:14"/>
Attachments	