

# Consultee Comment for planning application 6/2018/2170/FULL

<b>Application Number</b>	<input type="text" value="6/2018/2170/FULL"/>
<b>Location</b>	<input type="text" value="46 Lambs Close Cuffley Potters Bar EN6 4HD"/>
<b>Proposal</b>	<input type="text" value="Erection of third flat on the Airspace of 2x existing Flats."/>
<b>Case Officer</b>	<input type="text" value="Mr William Myers"/>
<b>Organisation</b>	<input type="text" value="WHBC - Client Services"/>
<b>Name</b>	<input type="text" value="Lorraine Davis"/>
<b>Address</b>	<input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="10/09/2018 - Lorraine Davis Can be incorporated on the existing ARRC scheme. There are 2 options for receptacles. If the bin store is large enough to accommodate 3 x 180l refuse bins and 3 x 240l recycling bins then each flat can have their own bins, if this is not then the 3 flats can share facilities and would require 2 x 240 litre refuse bins and 2 x 360l recycling bins. The bins would be provided FOC apart from 360l bins which cost ?40.00 each. The dimensions of the bins can be found on the WHBC website Bin Store guidance document."/>
<b>Received Date</b>	<input type="text" value="10/09/2018 10:42:07"/>
<b>Attachments</b>	