

Consultee Comment for planning application 6/2022/2284/COND

| | |
|---------------------------|--|
| Application Number | 6/2022/2284/COND |
| Location | Hertfordshire Constabulary Stanborough Road Welwyn Garden City AL8 6XF |
| Proposal | Submission of details pursuant to condition 2 (Construction environment management plan), 6 (Construction traffic management plan) and 15 (Fire hydrants) on planning permission 6/2021/2125/MAJ |
| Case Officer | Ms Louise Sahlke |
| Organisation | WHBC - Public Health and Protection |
| Name | Public Health and Protection |
| Address | WHBC - Public Health and Protection |
| Type of Comment | Comment |
| Type | |
| Comments | Comments from Environmental Health in relation to hours of operation for construction works: All noisy works and ancillary operations which are audible at the site boundary, or at such other place as may be agreed with the Council, shall be carried out only between the hours of: 8.00am and 6.00pm on Mondays to Fridays 8.00am and 1.00pm Saturdays and at no time on Sundays and Bank Holidays If noisy works must be carried out beyond these times, then an application must be made for consideration by environmental health under the Control of Pollution Act 1974 (Section 61 application). Reason ? to protect residents from noise from construction works beyond reasonable times |
| Received Date | 18/10/2022 09:59:01 |
| Attachments | |