

Consultee Comment for planning application 6/2023/1070/FULL

Application Number	<input type="text" value="6/2023/1070/FULL"/>
Location	<input type="text" value="Queenswood School Shepherds Way Hatfield AL9 6NS"/>
Proposal	<input type="text" value="Installation of roof mounted grid connected solar on the existing Sport Hall and Kenney and Essame Hall totalling 894 m2"/>
Case Officer	<input type="text" value="Ms Kirsty Shirley"/>
Organisation	<input type="text" value="North Mymms Parish Council"/>
Name	<input type="text" value="Christine Wootton"/>
Address	<input type="text" value="Clerk 1a Bushwood Close Welham Green AL9 7YZ"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="North Mymms Parish Council request the height of the units on the Kennedy and Essame Hall do not exceed 266mm from the finished roof level. It is noted that the gap between the units, which is only 140mm, would suggest that maintenance, ie cleaning, will be very difficult. At the end of the life of the solar panels and associated equipment, should be disposed of safely and in an environmentally appropriate manner."/>
Received Date	<input type="text" value="29/06/2023 08:46:05"/>
Attachments	