

Consultee Comment for planning application 6/2022/2759/FULL

Application Number	<input type="text" value="6/2022/2759/FULL"/>
Location	<input type="text" value="Plot 5610 Gypsy Moth Avenue Hatfield AL10 9BS"/>
Proposal	<input type="text" value="Erection of two industrial units for light industrial processes (E(g)(iii)) / general industrial (B2) / storage & distribution purposes (B8) and ancillary office space, with associated parking, access and supporting infrastructure"/>
Case Officer	<input type="text" value="Ms Kirsty Shirley"/>
Organisation	<input type="text" value="HCC Water Officer"/>
Name	<input type="text" value="Catherine Gilbert"/>
Address	<input type="text" value="Hertfordshire Fire and Rescue Service 9 Merchant Drive Mead Lane Hertford Hertfordshire SG13 7BH."/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="This will require a condition for the provision and installation of fire hydrants, at no cost to the county council, or fire and rescue service. This is to ensure there are adequate water supplies available for use in the event of an emergency."/>
Received Date	<input type="text" value="19/12/2022 08:58:04"/>
Attachments	