

Consultee Comment for planning application 6/2020/3451/MAJ

Application Number	6/2020/3451/MAJ
Location	Wells Farm Northaw Road East Cuffley Potters Bar EN6 4RD
Proposal	Demolition of existing buildings and erection of 14 dwellings
Case Officer	Mr Mark Peacock
Organisation	WHBC - Client Services
Name	Lorraine Davis
Address	Client Services The Campus Welwyn Garden City AL8 6AE
Type of Comment	ConditionalResponse
Type	
Comments	11/01/2021 Lorraine Davis - properties could be incorporated on the existing ARRC scheme and would receive a set of 2 bins for refuse & recycling 1 x 180l black bin for refuse and 1 x 240l Blue lidded bin for recycling plus a food waste caddy @ ?75.00 per dwelling Bins to be presented at boundary with highway the evening prior to collection & retrieved again after servicing. WHBC offer a chargeable Garden Waste Service at a cost of ?35.00 per annum. If required, the customer would need to contact WHBC and subscribe for the service and would receive a Brown bin for the garden waste service. Please resubmit tracking diagram using the attached freighter dimensions largest in fleet. The drag distances are in excess of what is acceptable (15m) both for residents and crew, this needs to be revised. No drag distance shown for BCP o/s H12 to freighter. Will BCP be a formal enclosure of some sort? consider resident whose house the BCP sits outside for neighbours bins, may be contentious?
Received Date	11/01/2021 15:57:50
Attachments	The following files have been uploaded: OLYMPUS One Pass 19 - 8x4MS Wide - Top Discharge Recycler - Euro 6 - RCV Data Sheet_20140130.pdf BS5906-2005.pdf