

**WELWYN HATFIELD BOROUGH COUNCIL
EXECUTIVE DIRECTOR - PLANNING, PUBLIC PROTECTION AND GOVERNANCE**

DELEGATED APPLICATION

Application No: 6/2018/1293/LAWP
Location: 21 Holme Road Hatfield AL10 9LH
Proposal: Certificate of lawfulness for a hip to gable roof alteration and construction of a rear dormer window
Officer: Ms Emily Stainer

Recommendation: Granted

6/2018/1293/LAWP

Context		
Application Description	Certificate of lawfulness for a hip to gable roof alteration and construction of a rear dormer window	
Relevant planning History	Application Number: E6/1967/1018/ Decision: Granted Decision Date: 14 June 1967 Proposal: Conservatory	
The main issues are:		
Whether the proposed works are permitted development by virtue of Schedule 2, Part 1, Class B (consisting of an addition or alteration to its roof) of the Town and Country Planning (General Permitted Development) (England) Order 2015 as amended		
	Yes / No	To be PD
Have permitted development rights been removed?	N	N
Is the property a dwellinghouse?	Y	Y
Is it detached or semi-detached?	Y	
Is it terraced?	N	
Is it within a conservation area?	N	
B.1 (a) Has permission to use the dwellinghouse as a dwellinghouse been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use)?	N	N
(b) would any part of the dwellinghouse, as a result of the works, exceed the height of the highest part of the existing roof	N	N
(c) would any part of the dwellinghouse, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway	N	N
(d) would the cubic content of the resulting roof space exceed the cubic content of the original roof space by more than:- (i) 40 cubic metres in the case of a terrace house, or (ii) 50 cubic metres in any other case	N	N
<i>Calculation:</i>		
<i>Volume of hip to gable: 2.31m x 4.14m x 7.31m /6 = 11.65m³</i>		
<i>Volume of rear dormer window: 2.4m x 3.6m x 4.83m /2 = 20.87m³</i>		

Total = 32.52 m3		
(e) would it consist of or include:- (i) the construction or provision of a veranda, balcony or raised platform, or (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe	N	N
(f) is the dwellinghouse on article 2(3) land (conservation area)	N	N
B.2 Development is permitted by Class B subject to the following conditions:- (a) the materials used in any exterior work shall be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse (b) is the enlargement constructed so that- (i) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension – (aa) the eaves of the original roof are maintained or reinstated: and (bb) the edge of the enlargement closest to the eaves of the original roof shall, so far as practicable, be not less than 20 centimetres from the eaves, measured along the roof slope from the outside edge of the eaves; and (ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse. (c) any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse shall be – (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed	Y Y N/A	
B.3 For the purposes of Class B “resulting roof space” means the roof space as enlarged, taking into account any enlargement to the original roof space, whether permitted by this class or not (refer (c) above.	Y	
B.4 For the purposes of paragraph B.2(b)(ii), roof tiles, guttering, fascias, barge boards and other minor roof details overhanging the external wall of the original dwellinghouse are not be considered part of the development.	N/A	

DRAWING NUMBERS

The development/works shall not be started and completed other than in accordance with the approved plans and details:

Plan Number	Revision Number	Details	Received Date
LP 01		Site Location Plan	16 May 2018
EX 11		Existing Ground and First Floor Plans	16 May 2018
EX 12		Existing Second Floor and Roof Plans	16 May 2018
EX 13		Existing Elevations	16 May 2018
P 11		Proposed Ground and First Floor Plans	16 May 2018
P 12		Proposed Second Floor and Roof Plans	16 May 2018
P 13		Proposed Elevations	16 May 2018

REASON: To ensure that the development is carried out in accordance with the approved plans and details.

Determined By:

Mr Mark Peacock
12 July 2018