## Rachel Legood

From: BCTAdmin@thameswater.co.uk

**Sent**: 27 April 2017 10:52

To: Planning

Subject: 3rd Party Planning Application - 6/2017/0624/MAJ

Head Of Development Control Welwyn Hatfield District Council Council Offices, Campus East Welwyn Garden City Hertfordshire

Your Ref: 6/2017/0624/MAJ

Our DTS Ref: 55053

27 April 2017

AL8 6AE

Dear Sir/Madam

Re: PLOT 5000, HATFIELD BUSINESS PARK, HATFIELD, HERTFORDSHIRE, AL10 9EZ

## **Waste Comments**

Following initial investigation, Thames Water has identified an inability of the existing waste water infrastructure to accommodate the needs of this application. Should the Local Planning Authority look to approve the application, Thames Water would like the following 'Grampian Style' condition imposed. "Development shall not commence until a drainage strategy detailing any on and/or off site drainage works, has been submitted to and approved by, the local planning authority in consultation with the sewerage undertaker. No discharge of foul or surface water from the site shall be accepted into the public system until the drainage works referred to in the strategy have been completed". Reason - The development may lead to sewage flooding; to ensure that sufficient capacity is made available to cope with the new development; and in order to avoid adverse environmental impact upon the community. Should the Local Planning Authority consider the above recommendation is inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Control Department (telephone 0203 577 9998) prior to the Planning Application approval.

## **Water Comments**

With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

## **Supplementary Comments**

We have no objection to foul water proposal. Regarding surface water: controlling flow rates from sites should be based on Qbar which for this site in equal 2.04l/s. We can accept greenfield runoff rate for 1 in 100 years, which is equal 6.5l/s and not 57l/s. Please recalculate greenfield runoff rate using IH124 method and adjust drainage strategy accordingly.

Yours faithfully Development Planning Department

Development Planning, Thames Water, Maple Lodge STW, Denham Way, Rickmansworth, WD3 9SQ Tel:020 3577 9998

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit www.thameswater.co.uk.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.