

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 12 September 2018 12:48  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 6/2018/2150/MAJ

WARNING: This email originated outside the WHBC Network. Please be extra vigilant when opening attachments or clicking links.

Head Of Development Control  
Welwyn Hatfield District Council  
Council Offices, Campus East  
Welwyn Garden City  
Hertfordshire  
AL8 6AE

Our DTS Ref: 54194  
Your Ref: 6/2018/2150/MAJ

12 September 2018

Dear Sir/Madam

Re: De Havilland Campus, University Of Hertfordshire, Mosquito Way, Hatfield, AL10

#### Waste Comments

Thames Water would advise that with regard to Foul Water sewage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided

Thames Water would advise that with regard to surface water network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

'We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [wwqriskmanagement@thameswater.co.uk](mailto:wwqriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality)."

#### Water Comments

With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)