

Sarah Nunn

From: Karl Riahi
Sent: 01 November 2017 15:25
To: Planning
Cc: Mark Peacock
Subject: 6/2017/2325/COND - Plot 6000

I am unable to recommend discharge of conditions 7 (Noise impact assessment) and 18 (Noise Survey) as the noise levels do not comply with the conditions of being 10dB below the background noise level at the nearest sensitive receptors.

Kind regards,

Karl Riahi
Environmental Health Officer
Welwyn Hatfield Borough Council
Telephone: 01707 357459
E-mail: k.riahi@welhat.gov.uk
www.welhat.gov.uk
@WelHatCouncil All Things Welwyn Hatfield