

David Elmore

---

Subject: FW: Consultation response

---

**From:** Oliver Waring  
**Sent:** 28 November 2017 16:59  
**To:** David Elmore <d.elmore@welhat.gov.uk>  
**Subject:** RE: Consultation response

Hi David,

I have taken a look at the plans supplied. In principle the scheme is sufficient, however further details is required:

- A tree protection plan and method statement to ensure the retained trees are protected throughout the development. These should be in accordance with BS: 5837: 2012
- Details of plants and trees used (some details have been supplied but not all). Species, size and planting densities.
- Planting methods and aftercare including watering.
- A condition that any plants that fail within the first five years are replaced.

I hope the above is of help. If you have any further queries let me know.

Kind regards,

Oliver

Oliver Waring  
**Tree Officer,**  
**Landscape & Ecology**

Welwyn Hatfield Borough Council  
The Campus  
Welwyn Garden City  
Herts AL8 6AE  
Telephone: 01707 357 000

Follow the link for more information about [Trees in Welwyn Hatfield](#).  
Find an [Arboricultural Association](#) approved tree surgeon or consultant