Head Of Development Control Welwyn Hatfield District Council Council Offices, Campus East Welwyn Garden City Hertfordshire AL8 6AE Our DTS Ref: 56930 Your Ref: 6/2017/2105/RM

1 February 2018

Dear Sir/Madam

Re: PLOT 4100, GYPSY MOTH AVENUE, HATFIELD BUSINESS PARK, HATFIELD, HERTFORDSHIRE, AL

Waste Comments

Thames Water would recommend that petrol / oil interceptors be fitted in all car parking/washing/repair facilities. Failure to enforce the effective use of petrol / oil interceptors could result in oil-polluted discharges entering local watercourses.

A Trade Effluent Consent will be required for any Effluent discharge other than a 'Domestic Discharge'. Any discharge without this consent is illegal and may result in prosecution. (Domestic usage for example includes - toilets, showers, washbasins, baths, private swimming pools and canteens). Typical Trade Effluent processes include: - Laundrette/Laundry, PCB manufacture, commercial swimming pools, photographic/printing, food preparation, abattoir, farm wastes, vehicle washing, metal plating/finishing, cattle market wash down, chemical manufacture, treated cooling water and any other process which produces contaminated water. Pre-treatment, separate metering, sampling access etc, may be required before the Company can give its consent. Applications should be made at https://wholesale.thameswater.co.uk/Wholesale-services/Business-customers/Trade-effluent or alternatively to Waste Water Quality, Crossness STW, Belvedere Road, Abbeywood, London. SE2 9AQ. Telephone: 020 3577 9200.

Surface Water Drainage - With regard to surface water drainage it is the responsibility of a developer to make proper provision for drainage to ground, water courses or a suitable sewer. In respect of surface water it is recommended that the applicant should ensure that storm flows are attenuated or regulated into the receiving public network through on or off site storage. When it is proposed to connect to a combined public sewer, the site drainage should be separate and combined at the final manhole nearest the boundary. Connections are not permitted for the removal of groundwater. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. The contact number is 0800 009 3921. Reason - to ensure that the surface water discharge from the site shall not be detrimental to the existing sewerage system.

'We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission:"A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake

to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing www.thameswater.co.uk. Application forms should be completed on line via www.thameswater.co.uk. Application forms should be completed on line via

Water Comments

Supplementary Comments

Thames Water will require the points of connection to the public sewer system, for both foul and surface water, as well as the anticipated flow (including flow calculation method) into any proposed connection point. This data can then be used to determine the impact of the proposed development on the existing sewer system. In addition please indicate what is the overall reduction in surface water flows. i.e. existing surface water discharges (pre-development) in to the public sewers for storm periods 1 in 10, 30, 100 etc... versus the new proposed volumes to be discharged for the whole development.

Yours faithfully Development Planning Department

Development Planning, Thames Water, Maple Lodge STW, Denham Way, Rickmansworth, WD3 9SQ <u>Tel:020</u> 3577 9998 Email: <u>devcon.team@thameswater.co.uk</u>

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to <u>devcon.team@thameswater.co.uk</u>