

**From:** [Town Planning LNE](#)  
**To:** [Planning](#)  
**Subject:** Ref 6/2022/1106/FULL - residential development, 1 Longcroft Green, Welwyn Garden City  
**Date:** 09 June 2022 11:50:30  
**Attachments:** [image001.png](#)  
[Standard Informatives.docx](#)  
[Standard Drainage Requirements.doc](#)

**\*\* WARNING: This email originated outside the WHBC Network. Please be extra vigilant when opening attachments or clicking links \*\***

### Network Rail Consultation Response

<b>FAO:</b>	Ms Louise Sahlke
<b>Date:</b>	9 June 2022
<b>Application reference:</b>	6/2022/1106/FULL
<b>Proposal:</b>	Erection of 1 detached 4 bed dwelling and detached 3 and a half storey building accommodating 6no. flats
<b>Location:</b>	1 Longcroft Green, Welwyn Garden City, AL8 6EP

Thank you for your recent correspondence relating to the above application.

Network Rail own, operate and develop Britain's railway infrastructure. Our role is to deliver a safe and reliable railway. All consultations are assessed with the safety of the operational railway in mind and responded to on this basis.

Following assessment of the details provided to support the above application, Network Rail has **no objection in principle to the development**, but below are some requirements which must be met, especially with the proximity of the development to high voltage overhead line equipment;

#### **Works in Proximity to the Operational Railway Environment**

##### **Development Construction Phase and Asset Protection**

Due to the proximity of the proposed development to the operational railway boundary, it will be imperative that the developer liaise with our Asset Protection Team (contact details below) prior to any work taking place on site to ensure that the development can be undertaken safely and without impact to operational railway safety. Details to be discussed and agreed will include construction methodology, earthworks and excavations, use of crane, plant and machinery, drainage and boundary treatments. It may be necessary for the developer to enter into a Basic Asset Protection Agreement (BAPA) with Network Rail to ensure the safety of the operational railway during these works.

##### **Condition**

*Development shall not commence until a construction methodology has been submitted to and approved in writing by the Local Authority. The construction methodology shall demonstrate consultation with the Asset Protection Project Manager at Network Rail. The development shall thereafter be carried out in accordance with the approved construction methodology unless otherwise agreed in writing by the Local Planning Authority.*

Contact details for Asset Protection are supplied below and **we would draw the developers' attention to the attached guidance on Network Rail requirements.**

##### **Drainage**

It is imperative that drainage associated with the site does not impact on or cause damage to adjacent railway assets. Surface water must flow away from the railway, there must be no ponding of water adjacent to the boundary and any attenuation scheme within 30m of the railway boundary must be approved by Network Rail in advance. There must be no connection to existing railway drainage assets without prior agreement with Network Rail. **Please note, further detail on Network Rail requirements relating to drainage and works in proximity to the railway infrastructure is attached for your reference.**

##### **Condition**

It is expected that the preparation and implementation of a surface water drainage strategy addressing these above points will be conditioned as part of any approval.

##### **Boundary Treatments, Landscaping and Lighting**

###### **Trespass Proof Fencing**

Trespass onto the railway is a criminal offence. It can result in costly delays to rail traffic, damage to the railway infrastructure and in the worst instances, injury and loss of life. Due to the nature of the proposed development we consider that there will be an increased risk of trespass onto the railway.

##### **Condition**

The developer must provide a suitable trespass proof fence adjacent to Network Rail's boundary (approx. 1.8m high) and make provision for its future renewal and maintenance. Network Rail's existing fencing/wall must not be removed or damaged.

###### **Vehicle Incursion Measures**

An Armco or similar barrier should be located in positions where vehicles may be in a position to drive into or roll onto the railway or damage the lineside fencing. Network Rail's existing fencing / wall must not be removed or damaged. Given the considerable number of vehicle movements likely provision should be made at each turning area/roadway/car parking area adjacent to the railway. This is in accord with the new guidance for road/rail vehicle incursion NR/LV/CIV/00012 following on from DfT advice issued in 2003, now updated to include risk of incursion from private land/roadways.

##### **Condition**

Given the nature of the proposals and location of turning areas/car parking, we would expect that a condition securing the design and installation of suitable vehicle incursion measures by the developer is included in any consent. This is for the safety, operational needs and integrity of the railway.

##### **Landscaping**

It is imperative that planting and landscaping schemes near the railway boundary do not impact on operational railway safety. Where trees and shrubs are to be planted adjacent to boundary, they should be positioned at a minimum distance greater than their height at maturity from the boundary. Certain broad leaf deciduous species should not be planted adjacent to the railway boundary. Any hedge planted adjacent to the railway boundary fencing for screening purposes should be placed so that when fully grown it does not damage the fencing, provide a means of scaling it, or prevent Network Rail from maintaining its boundary fencing. Below is a list of species that are acceptable and unacceptable for planting in proximity to the railway boundary;

###### **Acceptable:**

Birch (Betula), Crab Apple (Malus Sylvestris), Field Maple (Acer Campestre), Bird Cherry (Prunus Padus), Wild Pear (Pyrus Communis), Fir Trees – Pines (Pinus), Hawthorn (Cretaeagus), Mountain Ash – Whitebeams (Sorbus), False Acacia (Robinia), Willow Shrubs (Shrubby Salix), Thuja Plicatata "Zebрина"

###### **Not Acceptable:**

Acer (Acer pseudoplatanus), Aspen – Poplar (Populus), Small-leaved Lime (Tilia Cordata), Sycamore – Norway Maple (Acer), Horse Chestnut (Aesculus Hippocastanum), Sweet Chestnut (Castanea Sativa), Ash (Fraxinus excelsior), Black poplar (Populus nigra var. betulifolia), Lombardy Poplar (Populus nigra var. italica), Large-leaved lime (Tilia platyphyllos), Common lime (Tilia x europea)

##### **Condition**

Landscaping detail should be submitted to the Local Planning Authority and approved in conjunction with Network Rail.

##### **Lighting**

Where lighting is to be erected adjacent to the operational railway, the potential for train drivers to be dazzled must be eliminated. In addition, the location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway.

##### **Condition**

Detail of any external lighting should be provided to the Local Planning Authority to be approved in conjunction with Network Rail.

##### **Additional Requirements**

###### **Railway Noise Mitigation**

The Developer should be aware that any development for residential or noise sensitive use adjacent to an operational railway may result in neighbour issues arising. Consequently, every endeavour should be made by the developer to provide adequate soundproofing for each dwelling. Please note that in a worst-case scenario there could be trains running 24 hours a day and the soundproofing should take this into account.

###### **Reason for above conditions:**

**The safety, operational needs and integrity of the railway.**

###### **Informatives:**

**Please see attached standard railway requirements to be included as informatives.**

###### **Conclusion**

Thank you again for the opportunity to comment on the proposed scheme. We trust that the above will be given due consideration in determining the application and if you have any enquiries in relation to the above, please contact us at [townplanninglne@networkrail.co.uk](mailto:townplanninglne@networkrail.co.uk).

Useful Network Rail contacts;

###### **Asset Protection Eastern**

For enquiries, advice and agreements relating to construction methodology, works in proximity to the railway boundary, drainage works, or schemes in proximity to railway tunnels (including tunnel shafts) please email [assetprotectioneastern@networkrail.co.uk](mailto:assetprotectioneastern@networkrail.co.uk).

###### **Land Information**

For enquiries relating to land ownership enquiries, please email [landinformation@networkrail.co.uk](mailto:landinformation@networkrail.co.uk).

###### **Property Services**

For enquiries relating to agreements to use, purchase or rent Network Rail land, please email [propertyserviceslneem@networkrail.co.uk](mailto:propertyserviceslneem@networkrail.co.uk).

Kind regards



**Matt Leighton**  
Town Planning Technician  
**Diversity and Inclusion Champion**  
Network Rail Property - Eastern Region  
George Stephenson House, Toft Green, York, YO1 6JT

.....  
The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake, please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN.  
.....