

**From:** oliver.sowerby@hertfordshire.gov.uk  
**Sent:** 18 July 2018 09:40  
**To:** Planning  
**Subject:** Planning application 6/2018/1531/ADV - Plot 5000

WARNING: This email originated outside the WHBC Network. Please be extra vigilant when opening attachments or clicking links.

**Response to Planning application from Hertfordshire County Council (T and CP GDP Order 2015)**

**District ref:** 6/2018/1531/ADV  
**HCC ref:** WH/192/2018  
**HCC received:** 29/06/2018  
**Area manager:** Manjinder Sehmi  
**Case officer:** Oliver Sowerby

**Location**

Plot 5000  
Mosquito Way  
Hatfield  
AL10 9AY

**Application type**

Advertisement Consent

**Proposal**

Installation of 3 x Illuminated wall-mounted fascia signs

**Decision**

Notice is given under article 18 of the Town and Country Planning (Development Management Procedure) (England) Order 2015 that the Hertfordshire County Council as Highway Authority does not wish to restrict the grant of permission.

The Highway Authority does not wish to restrict the grant of planning permission.

**HIGHWAY INFORMATIVE:**

I recommend inclusion of the following Advisory Note (AN) to ensure that any works as part of this development are carried out in accordance with the provisions of the Highways Act 1980 and other relevant processes.

1). The intensity of illumination shall be controlled at a level that is within the limit recommended by the Institution of Lighting Engineers in the publication 'Technical Report No 5: Brightness of Illuminated Advertisements' and 'Guidance Notes for the Reduction of Obtrusive Light GN01:2011'.

**COMMENTS:**

The applicant seeks planning permission for the following development:

## Installation of 3 x Illuminated wall-mounted fascia signs

The Highway Authority note the specification of the signs as set out within the application form and elevation plans. The proposed signage is acceptable in principle. The Highway Authority recommend the inclusion of the aforementioned Advisory Note in order to ensure that the signs are in compliance with the provisions of the relevant lighting standards.

**Oliver Sowerby**

**Date 18/07/2018**

\*\*\*\*Disclaimer\*\*\*\* The information in this message should be regarded as confidential and is intended for the addressee only unless explicitly stated. If you have received this message in error it must be deleted and the sender notified. The views expressed in this message are personal and not necessarily those of Hertfordshire County Council unless explicitly stated. Please be aware that emails sent to or received from Hertfordshire County Council may be intercepted and read by the council. Interception will only occur to ensure compliance with council policies or procedures or regulatory obligations, to prevent or deter crime, or for the purposes of essential maintenance or support of the email system.