


DM

[REDACTED]

From: Damian Manhertz
Sent: 27 July 2010 16:24
To: Planning
Subject: FW: S6/2010/1359/MA - DHL - Frobisher Way



Please can I log these comment and upload to f.planning.

Thanks

Damian

From: Roger Evans
Sent: 27 July 2010 16:22
To: Damian Manhertz
Subject: S6/2010/1359/FP - DHL - Frobisher Way

Damian

I have looked at the application details and visited the site; my comments are as follows:-

This is a site where there is a great deal of activity, especially at night. Consequently there are high night-time noise levels associated with the traffic movements. For this reason, when the residential area was developed close to the Southern boundary extensive noise mitigation measures were necessary to protect the residents from excessive noise. These did not only include window and ventilation standards but also the provision of a long bund and fence to provide an acoustic barrier.

The proposed changes would result in some parking bays being provided closer to the houses, but no closer than the roadway itself which runs along the Northern end of the building. I have considered the possible impact noise issue if trailers were to be uncoupled at these closer parking positions, but do not believe the noise generated would compromise the attenuation standards provided.

In view of the above, I have no objections to this application.

Kind Regards

Roger Evans
Chartered Environmental Health Practitioner