

From: DataSpace Consult [system@dataspaceconsult.co.uk]
Sent: 03 October 2014 09:47
To: Planning
Subject: Comments Added: Land to the west Chequersfield WGC

03 OCT 2014

Dear Development

Please be aware that comments have been added to the following application:

Application Details:

Application ID: N6/2014/2008/FP - Mr H Laird Application Owner: Welwyn & Hatfield Borough Council(Development Management Officer)

Applicant: Network Rail

Location: Land to the west Chequersfield WGC Deadline Date: 22/10/2014 00:00:00

Description: Change of use to operational railway to facilitate installation of electricity feeder station Comment Added:

Commented By: e.health@welhat.gov.uk

- Comment: 1. Online works of 12 No pilling using DX-RT Hydraulic Hammer Rig. The use of the DX-RT Hydraulic Hammer rig shall only be carried out between the hours of 8:00 and 21:00 on Sunday the 5th October 2014 and in the event of overrunning works between the hours of 8:00 and 21:00 on Sunday 12th October 2014
2. Live acoustic field monitoring shall be carried out at sensitive receptors for the online operations detailed in item 1. The local authority shall be notified immediately of noise that exceeds the 80 dB(A) predicted noise levels on 07795 800756.
3. All off line works to the feeder station, compound works and ancillary operations which are audible at the site boundary, shall be carried out only between the hours of 08:00 and 18:00 on Mondays to Fridays and between the hours of 08:00 and 13:00 on Saturdays. Other than the consent given in item 1, no works shall be carried out on any Sundays and bank holidays
4. The best practicable means, as defined in section 72 of the Control of Pollution Act 1974, to reduce noise to a minimum shall be employed at all times
5. Acoustic barriers shall be erected for works associated with the compound construction and for activities that involving breaking out works
6. Perimeter screens, site hoardings and acoustic barriers shall be installed as soon as practicably possible to provide protection to reduce noise levels at noise sensitive premises
7. All plant being utilised on site shall be regularly inspected in order to demonstrate compliance with the plant list identified in the Section 61 application for the specific activity
8. Any emergency deviation from these conditions shall be notified to the undersigned without delay on 07795 800756
9. Near-field measurement shall be taken of all plant and machinery on site to demonstrate compliance with sound power levels details in the Section 61 application
10. A telephone number for emergency use shall be notified to the undersigned prior to the commencement of operations
11. A local contact point shall be made available to local residents and businesses during the works being undertaken in item 1 above
12. The consent will remain valid until 14th September 2015

Please click the following link to review these comments:

<http://www.consultlive.co.uk/index.aspx?appID=13449>