



- NOTES**
1. ALL DIMENSIONS IN MILLIMETERS.
 2. FLANGE CONNECTIONS TO BS EN 1092 PN16 UNLESS OTHERWISE STATED.
 3. TANK ACCESS HATCH.
 4. ACTIFLO OUTLET HEADER PIPE BY CLIENT.
 5. POSITION OF PAC SILO FILL PANEL TO BE OUTSIDE OF HAZARDOUS ZONED AREA.

- HOLDS**
1. PAC STORAGE SILO AND DOSING AWAITING CERTIFIED VENDOR INFORMATION.
 2. SERVICE WATER CONNECTION ASSUMED TO BE INSIDE OF ACTIFLO DOSING BUILDING, LOCATION TO BE CONFIRMED.
 3. NUMBER OF CABLE DUCTS AND DUCT SIZES REQUIRED TO BE DETERMINED BY TRANT. SIZE AND QUANTITY OF CABLE TRAYS REQUIRED TO BE CONFIRMED BY TRANT.

- REFERENCE DRAWINGS**
- GENERAL ARRANGEMENT DRAWINGS:**
- P018849-DR-381-0001 - ISOMETRIC VIEW
 - P018849-DR-381-0003 - ACTIFLO AREA PLAN
 - P018849-DR-381-0004 - ACTIFLO AREA SECTION PLAN
 - P018849-DR-381-0005 - ACTIFLO AREA SECTIONS
 - P018849-DR-381-0006 - ACTIFLO AREA SECTIONS
 - P018849-DR-381-0007 - ACTIFLO AREA SECTIONS
 - P018849-DR-381-0008 - ACTIFLO DOSING BUILDING PLAN
 - P018849-DR-381-0009 - ACTIFLO DOSING BUILDING SECTIONS

REV	PURPOSE FOR ISSUE	DRN	CHK	PROC	MECH	EICA	APP
B	EQUIPMENT NOT IN VEOLIA SCOPE DELETED	DJB	-	-	JR	GS	OR
		26.9.18	-	-	26.9.18	26.9.18	26.9.18

VEOLIA

VEOLIA WATER TECHNOLOGIES
AQUA HOUSE,
2620 KINGS COURT,
BIRMINGHAM BUSINESS PARK,
BIRMINGHAM. B37 7YE
TEL: 0203 567 7400

TRANT

TRANT Engineering Ltd.
Head Office: Rushington House,
Rushington,
Southampton SO40 9LT.
Telephone: (023) 8066 5544
E-Mail: engineering@trant.co.uk

Rev	Description	Design	Check	Approve	Date
A	PRELIMINARY ISSUE	DJB	-	MK	21.09.18
B	EQUIPMENT NOT IN VEOLIA SCOPE DELETED	DJB	-	OR	26.09.18

Affinity Water

Affinity Water Limited
Tomblin Way
Hatfield
Herts. AL10 9EZ

Site: **NORTH MYMMS**

Project: **METALDEHYDE REMOVAL**

Title: **GENERAL ARRANGEMENT OVERALL PLAN/SECTION**

Job No:	Sheet Size:	A1	Scale:	1:75
Design:	DJB	Checked By:	-	Approved By:
Sheet 1 of 1 Sheets	Dos Location:		Rev:	
Drawing No:	P018849-DR-381-0002			B