

Ann Helmke

From: BCTAdmin@thameswater.co.uk
Sent: 21 June 2018 12:01
To: Planning
Subject: 3rd Party Planning Application - 6/2018/1519/MAJ

WARNING: This email originated outside the WHBC Network. Please be extra vigilant when opening attachments or clicking links.

Head Of Development Control
Welwyn Hatfield District Council
Council Offices, Campus East
Welwyn Garden City
Hertfordshire
AL8 6AE

Our DTS Ref: 58280
Your Ref: 6/2018/1519/MAJ

21 June 2018

Dear Sir/Madam

Re: Land north of, Chequersfield, WELWYN GARDEN CITY, HERTFORDSHIRE, AL7

Waste Comments

Thames Water would advise that with regard to waste water network and waste water process infrastructure capacity, we would not have any objection to the above planning application, based on the information provided

With regard to surface water drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://developers.thameswater.co.uk/Developing-a-large-site/Apply-and-pay-for-services/Wastewater-services>

As you are redeveloping a site, there may be public sewers crossing or close to your development. If you discover a sewer, it's important that you minimize the risk of damage. We'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development/Working-near-or-diverting-our-pipes>.

Water Comments

With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk