

From: BCTAdmin@thameswater.co.uk
To: [Planning](#)
Subject: 3rd Party Planning Application - 6/2018/2768/OUTLINE
Date: 12 December 2018 15:35:38

Head Of Development Control
Welwyn Hatfield District Council
Council Offices, Campus East
Welwyn Garden City
Hertfordshire
AL8 6AE

Our DTS Ref: 44484
Your Ref: 6/2018/2768/OUTLINE

12 December 2018

Dear Sir/Madam

Re: ASTWICK MANOR LODGE, COOPERS GREEN LANE, HATFIELD, HERTFORDSHIRE, AL10 9BP

Waste Comments

Following initial investigations, Thames Water has identified an inability of the existing foul water network infrastructure to accommodate the needs of this development proposal. Thames Water request that the following condition be added to any planning permission. No properties shall be occupied until confirmation has been provided that either:- all wastewater network upgrades required to accommodate the additional flows from the development have been completed; or- a housing and infrastructure phasing plan has been agreed with Thames Water to allow additional properties to be occupied. Where a housing and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed housing and infrastructure phasing plan. Reason - The development may lead to sewage flooding and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional flows anticipated from the new development. Any necessary reinforcement works will be necessary in order to avoid sewer flooding and/or potential pollution incidents." The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

The application indicates that surface waters will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Water Comments

With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk