

3990 - Chequersfield - Taylor Wimpey North Thames

Part L Criterion 3 (Overheating) - Threshold Temperatures in Summer Months

	Property Ref	June	July	August	<23.5 Degrees?
Block A	4907-0015-3990-001	21.04	22.94	22.54	Yes
	4907-0015-3990-002	21.40	23.33	23.07	Yes
	4907-0015-3990-003	19.91	21.90	21.67	Yes
	4907-0015-3990-004	19.31	21.31	21.01	Yes
	4907-0015-3990-005	18.81	20.86	20.68	Yes
	4907-0015-3990-006	18.46	20.53	20.38	Yes
	4907-0015-3990-007	19.31	21.31	21.01	Yes
	4907-0015-3990-008	18.81	20.86	20.68	Yes
	4907-0015-3990-009	18.46	20.53	20.38	Yes
	4907-0015-3990-010	19.73	21.73	21.43	Yes
	4907-0015-3990-011	19.27	21.32	21.14	Yes
	4907-0015-3990-012	18.97	21.04	20.89	Yes
Block B	4907-0015-3990-013	20.47	22.41	22.10	Yes
	4907-0015-3990-014	20.86	22.84	22.71	Yes
	4907-0015-3990-015	20.69	22.62	22.29	Yes
	4907-0015-3990-016	21.12	23.09	22.95	Yes
	4907-0015-3990-017	19.85	21.84	21.62	Yes
	4907-0015-3990-018	19.69	21.69	21.48	Yes
	4907-0015-3990-019	18.64	20.69	20.50	Yes
	4907-0015-3990-020	19.09	21.13	20.99	Yes
	4907-0015-3990-021	18.76	20.80	20.59	Yes
	4907-0015-3990-022	19.12	21.18	21.09	Yes
	4907-0015-3990-023	18.14	20.23	20.10	Yes
	4907-0015-3990-024	18.63	20.69	20.53	Yes
	4907-0015-3990-025	18.96	21.01	20.82	Yes
	4907-0015-3990-026	19.40	21.45	21.31	Yes
	4907-0015-3990-027	19.10	21.15	20.97	Yes
	4907-0015-3990-028	19.64	21.70	21.60	Yes
	4907-0015-3990-029	18.65	20.73	20.60	Yes
	4907-0015-3990-030	19.16	21.22	21.05	Yes

NB: Dwellings with internal threshold temperatures of less than 23.5 degrees are not deemed to be at significant risk of overheating in line with Part L Criterion 3.