

Consultee Comment for planning application 6/2020/0807/COND

Application Number	6/2020/0807/COND
Location	Chequers Field Welwyn Garden City AL7 4SX
Proposal	Submission of details pursuant to condition 1 (scheme of remediation) on planning permission 6/2018/1519/MAJ
Case Officer	Mrs Sarah Madyausiku
Organisation	WHBC - Public Health and Protection
Name	Public Health and Protection
Address	WHBC - Public Health and Protection
Type of Comment	Comment
Type	
Comments	Sufficient information has been supplied in terms of the proposed remediation scheme to discharge the condition. Information is still required to show that the gas membrane and any other parts of the remediation scheme have been suitably installed through a verification report. This forms a separate section of the standard contaminated land condition which is broken up into sections, the requirement of a remediation scheme being one of those sections.
Received Date	27/04/2020 13:17:07
Attachments	