

# Consultee Comment for planning application 6/2020/1066/COND

<b>Application Number</b>	6/2020/1066/COND
<b>Location</b>	Chancellors School Pine Grove Hatfield AL9 7BN
<b>Proposal</b>	Submission of details pursuant to condition 6 (sample of materials) and 7 (details of external lighting scheme) on planning permission 6/2019/0085/MAJ
<b>Case Officer</b>	Mr David Elmore
<b>Organisation</b>	WHBC - Public Health and Protection
<b>Name</b>	Public Health and Protection
<b>Address</b>	WHBC - Public Health and Protection
<b>Type of Comment</b>	Comment
<b>Type</b>	
<b>Comments</b>	Although it is not clear if the lighting plan shows vertical lux levels, taking into account the luminaires to be installed which are shown on the lighting plan, the lux levels (even if horizontal) and the distance to residential properties makes it appear that issues from lighting will be unlikely. As such, condition 7 (details of external lighting scheme) can be discharged.
<b>Received Date</b>	09/06/2020 09:30:36
<b>Attachments</b>	