

Director of Environment & Infrastructure:
Mark Kemp



William Myers
Welwyn Hatfield Borough Council
The Campus
Welwyn Garden City
Hertfordshire
AL8 6AE

Post Point CHN 215
Hertfordshire County Council
County Hall, Pegs Lane
HERTFORD SG13 8DN

Contact David Uncle
Email FRMConsultations@hertfordshire.gov.uk

Date 17 July 2020

RE: 6/2020/1181/COND – Northaw House, Coopers Lane, Northaw, Potters Bar, EN6 4NG

Dear William,

Thank you for consulting us on the above application for the submission of details pursuant to condition 1 (surface water drainage scheme) on planning permission 6/2019/0217/MAJ at Northaw House, Coopers Lane, Northaw, Potters Bar, EN6 4NG.

Condition 1 states:

No development shall take place until a detailed surface water drainage scheme for the site based on the approved drainage strategy and sustainable drainage principles, has been submitted to and approved in writing by the local planning authority. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed. The scheme shall include:

- a) *Final, detailed drainage scheme including a detailed drainage layout and detailed calculations;*
- b) *Detailed assessment of the culverted drainage connection from the site into the ordinary watercourse including CCTV survey to justify any additional maintenance and repair works needed prior implementation of the approved drainage scheme. If discharge to the Ordinary Watercourse of the surface water run-off generated from the site will not be feasible then an alternative discharge mechanism should be provided;*
- c) *Detailed engineered drawings of the proposed SuDS features including cross section drawings, their size, volume, depth and any inlet and outlet features including any connecting pipe runs; and*
- d) *Final detailed management plan to include arrangements for adoption and any other arrangements to secure the operation of the scheme throughout its lifetime.*

The scheme shall be fully implemented and subsequently maintained, in accordance with the timing / phasing arrangements embodied within the scheme, or within any other period as may subsequently be agreed, in writing, by the Local Planning Authority.

REASON: To prevent flooding by ensuring the satisfactory storage of/disposal of surface water from the site. To comply with Policies R5 and R7 of the Welwyn Hatfield District Plan 2005 and in accordance with the National Planning Policy Framework 2019.

We have reviewed the covering note and appendices prepared by Civilistix reference DRM/CIV/1-046 dated May 2020 submitted in support of this application.

We advise the LPA that the information submitted in support of condition 1 in relation to surface water does comply with the requirements of the condition. Therefore, we recommend that the LPA does discharge condition 1.

We are pleased that a drainage layout has been submitted.

The applicant has confirmed that all surface water pipework is being replaced apart from the culverted section under the highway, which is to be reused. We understand this culvert will be fully cleared and jetted and will connect to a headwall to the ordinary watercourse.

The applicant has provided calculations for the 1 in 100 year + 40% climate change event and confirms that the basin size has been increased to provide a total volume of 1480 m³, which will provide attenuation for the 1 in 100 year + 40% climate change storm followed by a 1 in 30 year storm.

Informative to the LPA/applicant

The applicant should be aware that any works proposed to be carried out that may affect the flow within an ordinary watercourse will require the prior written consent from the Lead Local Flood Authority under Section 23 of the Land Drainage Act 1991. This includes any permanent and or temporary works regardless of any planning permission.

Please note that if the LPA decides to discharge condition 1 we ask to be notified for our records.

Yours sincerely,

David Uncle
SuDS Officer
Environmental Resource Planning