



RD20 Threaded Lifting Loop Safe Working Load: 2000kg each

Manufactured from zinc plated steel wire rope with a precision bright steel threaded portion. Threaded lifting loops are ideally suited to axial lifting procedures but can be used up to and including angled lifts of 30 degrees.

Use and Operation

The threaded lifting loop must be fully threaded into the lifting socket prior to commencing a lifting operation. It is imperative that the two mating surfaces are parallel to each other.

NOTES:

All dime nsions in mm

<u>Specification Information</u>

Opening in back wall cast to suit outside diameter of the pipeworl

Invert level of pipe can be set to your specification

Units should be bedded on minimum 150mm of semi-dry concrete.

Sit the headwall level or with a slight fall 1:50 from pipe to spill mouth.

Handling

A. Weight of concrete is based on 2.4 tonne/m³+5% is recommended for sizing lifting equipment. All lifting points shall be used as specified below - Anchor points & loops - Total

- Unit to be lifted as per lifting diagram

- Mix ref: Self-compacting DC4/DS4 Mix Lifting strength based on 2 cubes = 20N/mm² Characteristic 28 day cube strength = 50N/mm²
- Concrete provides Design Chemical Class 4 (DC4) to special Digest 1, Table F2.

- Reinforcement
 A. Reinforcement to BS EN 13369
- Scheduling, dimensioning, bending & cutting to BS8666
 Cage to be machine tied with steel wire

- Manufacture to BS EN 15258:2008 precast concrete products Retaining wall elements, Factory Production Control certificate number: 0086-CPR-650448 & BS EN 13369
- Tolerances to BS EN 13369 clause 4.3.1.1

- Marking: Units shall be indelibly marked to show Mould reference code
- De-mould date
- Unit weight (kg)

Concrete design to EC2

- Althon have designed the concrete units only, the site conditions should be assessed for suitability by the scheme designer
- Units are designed to withstand a vertical live load surcharge of 10kN/M² Weight of soil = 18kN/M² Angle of internal friction = 30 Deg.
- Design Life: >50 years

MIII COVO	Size (mm)		(mm)	Size (mm)			
All Faces	33		28	38			
	Exposure induced by Carbonation		Corrosion induced by Chloride		F	reeze/thaw attack	Che

All Faces XC3/4 XD2 XF3 XA2

Fabrication Specification

A. Manufacture IAW EN 1090-2 EXC CLASS 1

Material grade is to be: BS EN 10025 S275
Welding carried out IAW EN 1090-2 PARA 7.5.4 - 7.5.18

- All fillet and butt welds to have a minimum throat thick fully welded where possible.
- Ensure vertical flats are fully welded both sides where possible All sharp edges and burrs are to be removed
- Remove all weld splatter.
- Holes by punching are permitted with reaming.
 Galvanising is carried out after fabrication to BS EN:ISO 1461

- Kee Klamp® Galvanised Size 8 Fittings Size 8 48.3mm OD 3.2mm Wall Thickness Galvanised Medium Duty Tube to BS EN 10255 360N/m Design Load at stated in BS 8118, BS 6180, BS 6399 & BS 7818, Civil
- Engineering Specification for thw Water Industry (CESWI) 7th Edition Clause 2.60 Handrails & Balusters & The Engineering Equipment and Materials Users' Association (EEMUA) Publication 105 7th Edition Factory Stairways, Ladders and
- Other design loads available on request GRP/FRP Handrails also available

DESCRIPTION REV NO The information contained in this drawing is the sole property of Althon Limited. Any reproduction in part or as a whole without the written permission of Althon Limited is strictly prohibited.

DRAWING TITLE / PROJECT:

Headwall Lifting Diagram

NTS 02 OF 02 26 - 04 - 18 1150kg N/A PRODUCT NAME H6CA

