

# Comment for planning application 6/2022/0628/FULL

<b>Application Number</b>	6/2022/0628/FULL
<b>Location</b>	Campus West The Campus Welwyn Garden City Hertfordshire AL8 6BX
<b>Proposal</b>	Installation an Air Source Heat Pump (revision to approved scheme 6/2021/1788/FULL).
<b>Case Officer</b>	Mr Raymond Lee
<b>Organisation</b>	
<b>Type of Comment</b>	Objection
<b>Type</b>	neighbour
<b>Comments</b>	<p>We object to the installation of the proposed Air Source Heat Pump (ASHP) because even after the mitigation there will still be an adverse noise impact of around 2dB above the evening background level (up 15%). We note that the Plant noise assessment report by Hepworth Acoustics points out that a 10 dB increase in noise means a doubling of the noise level ie a 100% increase. Without the acoustic barriers the increase would be between 5 &amp; 7 dB which implies something like a 50% increase in noise which is totally unacceptable. You should be striving to lessen noise pollution, air pollution and anti social behaviour not increase it with these undesirable plans. This project must be heard by the DMC and not decided under delegated powers. The size and positioning of this ASHP is not appropriate and a blight to residents and the Town in general. It is an industrial size machine and will be VERY NOISY indeed. We should not be industrializing a residential area of the Garden City.</p>
<b>Received Date</b>	30/04/2022 21:35:36
<b>Attachments</b>	