

Planning Consultation Memo

Date	Planning Officer	Environmental Health Officer
06/07/2022	Ms Emily Stainer	Terry Vincent
Planning Application Number	Worksheet Number	
6/2022/0863/FULL	WK131195	

Address: Unit 13 Peartree Farm Welwyn Garden City AL7 3UW

Application Details: Erection of detached two-storey brick building for E(g) use with designated parking spaces for 6 vehicles and secure storage housing for 6 bicycles following demolition of existing timber building

Considerations relevant to Environmental Health for this application

Noise from construction works.
Noise from any plant and equipment.
Contaminated Land.

Description of site and discussion of considerations

Noise from plant and equipment:

If there are plans to install any plant or equipment such as air conditioning for the proposed development, then it must comply with the council's noise requirements. I will recommend that a condition is attached to any approval.

Contaminated land:

Given the nature of the locality, I recommend the application of an unexpected finds condition, just in case any contaminated land is encountered any stages of the development.

Conclusion

Recommend planning application is permitted
Recommend planning application is permitted but with conditions
Recommend planning application is refused

Conditions:

Noise from demolition/construction works:

All noisy works and ancillary operations which are audible at the site boundary, or at such other place as may be agreed with the Council, shall be carried out only between the hours of:

8.00am and 6.00pm on Mondays to Fridays

8.00am and 1.00pm Saturdays
and at no time on Sundays and Bank Holidays

If noisy works must be carried out beyond these times, then an application must be made for consideration by environmental health under the Control of Pollution Act 1974 (Section 61 application).

Reason – to protect residents from noise from construction works beyond reasonable times

New Plant:

The applicant shall submit to, for approval in writing by the Local Planning Authority, details relating to a scheme to mitigate the noise from new plant and equipment. The impact of new plant and equipment should be assessed in accordance with BS4142: 2014+A1:2019. When noise sources show signs of tonality, we require noise levels to be 10dB below background noise level at the nearest receptor location. In instances where the noise source presents no tonality, we require the noise level to be 5dB below the background noise level at the nearest receptor location.

Reason – to protect neighbours from noise disturbance.

Contaminated land:

1. Reporting of Unexpected Contamination: In the event that contamination is found at any time when carrying out the approved development that was not previously identified it must be reported in writing immediately to the Local Planning Authority. An investigation and risk assessment must be undertaken in accordance with the requirements of condition 2, and where remediation is necessary a remediation scheme must be prepared in accordance with the requirements of condition 2, which is subject to the approval in writing of the Local Planning Authority. Following completion of measures identified in the approved remediation scheme a verification report must be prepared, which is subject to the approval in writing of the Local Planning Authority in accordance with condition 2.

Reason: To ensure that risks from land contamination to the future users of the land and neighbouring land are minimised, together with those to controlled waters, property and ecological systems, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

2. Prior to the commencement of development approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved, in writing, by the local planning authority:

- i) A preliminary risk assessment which has identified:
 - all previous uses
 - potential contaminants associated with those uses

- a conceptual model of the site indicating sources, pathways and receptors
- potentially unacceptable risks arising from contamination at the site.

ii) A site investigation scheme, based on (i) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site. This should include an assessment of the potential risks to: human health, property (existing or proposed) including buildings, crops, pests, woodland and service lines and pipes, adjoining land, ground waters and surface waters, ecological systems, archaeological sites and ancient monuments.

iii) The site investigation results and the detailed risk assessment (ii) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

iv) A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in (iii) are complete and identifying any requirements for longer term monitoring of pollutant linkages, maintenance and arrangements for contingency action. Any changes to these components require the express consent of the local planning authority. The scheme shall be implemented as approved.

Reason: To ensure that risks from land contamination to the future users of the land and neighbouring land are minimised, together with those to controlled waters, property and ecological systems, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

3. Following completion of measures identified in the approved remediation scheme and prior to the first use or occupation of the development, a verification report that demonstrates the effectiveness of the remediation carried out must be produced together with any necessary monitoring and maintenance programme and copies of any waste transfer notes relating to exported and imported soils shall be submitted to the Local Planning Authority for approval. The approved monitoring and maintenance programme shall be implemented.

Reason: To ensure that risks from land contamination to the future users of the land and neighbouring land are minimised, together with those to controlled waters, property and ecological systems, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

The above must be undertaken in accordance with the Environment Agency's 'Land contamination risk management (LCRM)' guidance, available online at <https://www.gov.uk/government/publications/land-contamination-risk-management-lcrm>.

Informative:

Demolition/construction works

1. The best practicable means, as defined in section 72 of the Control of Pollution Act 1974, to reduce noise to a minimum shall be employed at all times
2. All plant and machinery in use shall be properly silenced and maintained in accordance with the manufacturers' instructions
3. All compressors shall be sound reduced models, fitted with properly lined and sealed acoustic covers, which shall be kept closed whenever the machines are in use. All ancillary pneumatic percussive tools shall be fitted with mufflers or silencers of the type recommended by the manufactures.
4. All machines in intermittent use shall be shut down during intervening periods between work, or throttled down to a minimum. Noise emitting equipment, which is required to operate continuously, shall be housed in suitable acoustic enclosures.
5. Items of plant and equipment shall be maintained in good condition so that extraneous noise from mechanical vibration, squeaking or creaking is reduced to a minimum.
6. All pile driving shall be carried out by a recognised noise reducing system.
7. Where practical, rotary drills and bursters, actuated by hydraulic or electric power shall be used for excavating hard material
8. In general, equipment for breaking concrete and the like, shall be hydraulically actuated.
9. 'BS 5228 Noise Control on Construction Sites' should be referred to for guidance in respect of all work carried out by the developer, their main contractor and any sub contractors.
10. Any emergency deviation from these conditions shall be notified to the Council without delay
11. Any planned deviations from these conditions for special technical reasons, shall be negotiated with Council at least 14 days prior to the commencement of the specific work.
12. Permissible noise levels are not specified at this stage.

Dust control

1. All efforts shall be made to reduce dust generation to a minimum
2. Stock piles of materials for use on the site or disposal, that are likely to generate dust, shall be sited so as to minimise any nuisance to residents or neighbouring businesses. Materials for disposal shall be moved off site as quickly as possible.

3. Water sprays shall be used, as and when necessary, to reduce dust from particularly "dusty" activities or stock piles.