

Consultee Comment for planning application 6/2022/2801/MAJ

Application Number	6/2022/2801/MAJ
Location	Campus East Car Park College Way Welwyn Garden City AL8 6DG
Proposal	Demolition of all existing buildings and structures followed by the erection of five buildings to provide 313 residential units (Use Class C3); car and cycle parking, cycle and refuse storage, hard and soft landscaping, external lighting, drainage, infrastructure and all associated works.
Case Officer	Mr Nabeel Kasmani
Organisation	WHBC - Client Services
Name	Lorraine Davis
Address	Client Services The Campus Welwyn Garden City AL8 6AE
Type of Comment	ConditionalResponse
Type	
Comments	09/01/2023 ...cont. Block A look to be well in excess of 15m drag distance. Please provide drag distances and more detail on block A route to freighter i.e. distance, slopes etc. Bin requirements by Block: Block A1 - 6 x 1100's, 1 x MRC, 3 x food waste. Block A2 - 5 x 1100's, 1 x MRC, 4 x food waste Block A3 - 3 x 1100's, 1 x MRC, 3 x food waste. Block A4 - 3 x 1100's, 1 x MRC, 3 x food waste Block B1 - 5 x 1100's, 1 x MRC, 3 x food waste. Block B2 - 1 x 1100 1 x 240l refuse, 1 x MRC, 2 x food waste Block B3 - 3 x 1100's, 1 x MRC, 2 x food waste. Blcok B4 - 3 x 1100's, 1 x MRC, 2 x food waste Block C - 1 x 1100 1 x 240l refuse, 1 x MRC 1 x food waste. Block D - 2 x 1100's, 1 x MRC, 2 x food waste Block E - 4 x 1100's, 1 x MRC, 3 x food waste. Block F - 2 x 1100, 1 x 360l refuse, 1 x MR, 2 x food waste Block G - 2 x 1100's, 1 x 240l refuse, 1 x MRC, 2 x food waste. Block H - 4 x 1100's, 1 x MRC, 3 x food waste
Received Date	09/01/2023 15:07:38
Attachments	