

Consultee Comment for planning application 6/2024/1367/COND

Application Number	6/2024/1367/COND
Location	29 Broadwater Road Welwyn Garden City Hertfordshire AL7 3BQ
Proposal	Submission of details pursuant of condition 11 and 34 (refuse and recycling) on planning permission 6/2019/3024/MAJ
Case Officer	Ms Louise Sahlke
Organisation	WHBC - Client Services
Name	Lorraine Davis
Address	Client Services The Campus Welwyn Garden City AL8 6AE
Type of Comment	ConditionalResponse
Type	
Comments	22/07/2024 Lorraine Davis - The refuse strategy varies considerably from the original submission which showed 3 bin stores. Please provide an accommodation schedule that advises how many of each type of flat (i.e. how many 1 beds, 2 beds, 3 beds etc) share each bin store so I can ensure that the calculations for receptacles is correct, the diagram shows a selection of bin sizes in the different stores and I need to advise exactly what you need for each for waste, recycling & food. In addition Bins store G is in excess of the 15m maximum drag distance allowed from store to freighter so would need reviewing.
Received Date	22/07/2024 11:40:15
Attachments	