

# Consultee Comment for planning application S6/2015/1342/PP

<b>Application Number</b>	<input type="text" value="S6/2015/1342/PP"/>
<b>Location</b>	<input type="text" value="Land to the north east of King George V Playing Fields, Northaw Road East, Cuffley, Hertfordshire, EN6 4RD"/>
<b>Proposal</b>	<input type="text" value="Outline planning application for residential development of up to 121 dwellings, associated infrastructure and a change of use from agricultural land to an extension of the King George V playing field. All matters reserved except for new vehicular access to serve the site, the provision of surface water discharge points and the levels of development platforms"/>
<b>Case Officer</b>	<input type="text" value="Mr Mark Peacock"/>
<b>Organisation</b>	<input type="text" value="Herts Fire &amp; Rescue Service"/>
<b>Name</b>	<input type="text" value="Mr John Parker"/>
<b>Address</b>	<input type="text" value="Herts Fire &amp; Rescue Service Community Fire Safety Longfield Hitchin SG1 4AE"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="From the drawings there is insufficient detail, therefore please find below the requirements of Hertfordshire Fire &amp; Rescue. ACCESS AND FACILITIES 1. Access for fire fighting vehicles should be in accordance with The Building Regulations 2019 Approved Document B Vol 1 B5 section 13 2. Access routes for Hertfordshire Fire and Rescue Service vehicles should achieve a minimum carrying capacity of 19 tonnes. B5. WATER SUPPLIES 4. Water supplies should be provided in accordance with ADB Vol 1 B5 section 14, for enquires relating to hydrant matters within the Hertfordshire area, you should contact the Water Officer on 01992 507521. Correspondence can be sent to: The Water Officer, Hertfordshire Fire &amp; Rescue Services Headquarters, Old London Road, Hertford, Hertfordshire SG13 7LD. ."/>
<b>Received Date</b>	<input type="text" value="22/07/2021 14:00:41"/>
<b>Attachments</b>	