


Ack

RA/KC

M [Redacted]
F [Redacted]

Sent: 01 April 2011 08:27
To: Planning
Subject: Comments Added: Former Shredded Wheat Factory, Broadwater Road West, Welwyn Garden City



Dear Development

Please be aware that comments have been added to the following application:

Application Details:

Application ID: N6/2010/2055/MA - Mr R Aston Application Owner: Welwyn & Hatfield Borough Council(Development Control Officer)
Applicant: DP9
Location: Former Shredded Wheat Factory, Broadwater Road West, Welwyn Garden City Deadline Date: 16/03/2011 00:00:00
Description: Revised EIA Documents
Comment Added:

Commented By: [Redacted]
Comment: Dear Sir,
Our Reference 19/37236v

1st April 2011

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (APPLICATION) REGULATIONS 1988 The Former Shredded Wheat Factory. WGC

We make the following comments:

ACCESS AND FACILITIES

1. Access for fire fighting vehicles should be in accordance with The Building Regulations 2000 Approved Document B (ADB), section B5 sub-section 16.
2. Access routes for Hertfordshire Fire and Rescue Service vehicles should achieve a minimum carrying capacity of 20 tonnes.

WATER SUPPLIES

3. Water supplies should be provided in accordance with BS 9999.
4. This authority would consider the following hydrant provision adequate:
 - Not more than 60m from an entry to any building on the site.
 - Not more than 90m apart for commercial developments.
 - Preferably immediately adjacent to roadways or hard-standing facilities provided for fire service appliances.
 - Not less than 6m from the building or risk so that they remain usable during a fire.
 - Hydrants should be provided in accordance with BS 750 and be capable of providing an appropriate flow in accordance with National Guidance documents.

Rob Devereux
Fire Protection Inspecting Officer

Please click the following link to review these comments:

<http://www.consultlive.co.uk/index.aspx?appID=6476>

Any reply to this email will be logged against the consultation.

If you have problems with this link, please email the Consult-Live help team - helpdesk@resolutiondm.com quoting reference: EM004

Powered by DataSpace Consult Live www.consultlive.co.uk

Powered by devMail.Net (Free Version) - The Most Powerful .Net Email Component.
devMail.Net is not the sender of this email nor responsible for the content.