

From: Miriam Hill
Sent: 17 November 2014 19:11
To: Mark Peacock; Planning
Subject: S6/2014/2292/FP: Lands Southeast of Northaw Road East (Cattlegate Farm), Cuffley

Description: Installation of pipework to provide a primary distribution heat network

There does not appear to be any information relating to the installation of the pipe in relation to the adjacent trees, especially along the roadside of Northaw Road East and adjacent to Wells Farm. I would have expected, at least, an Arboricultural Implications Assessment in accordance with BS5837. This level of trenching within the RPA of the trees would result in significant damage to the root zone and at least would be detrimental to their health at worst the trees could just fall over if all the primary roots are severed on one side.

I object due to lack of specific information.

Thank you

Miriam Hill
Tree Officer

