

Consultee Comment for planning application 6/2017/2160/COND

Application Number	<input type="text" value="6/2017/2160/COND"/>
Location	<input type="text" value="Mercury House 1 Broadwater Road Welwyn Garden City AL7 3BQ"/>
Proposal	<input type="text" value="Submission of details pursuant to condition 1 (materials samples), 2 (soft and hard landscaping), 6 (bin stores) and 7 (cycle stores) on planning permission 6/2016/2624/FULL, dated 14/09/2017"/>
Case Officer	<input type="text" value="Ms R Collard"/>
Name	<input type="text" value="Lorraine Davis"/>
Address	<input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>
Type of Comment	<input type="text" value="ConditionalResponse"/>
Type	<input type="text"/>
Comments	<input type="text" value="9/10/2017 - Lorraine Davis Location of Bin Stores is acceptable. Notes on design: I would recommend only 2 x Mini Recycling banks are required not 4 and that they are stored in one bin store with double doors rather than separate ones each with double doors. The slope leading from the bin stores to the collection point needs to be a minimum of 2m wide it presently looks the same as the 1100litre container which is only 125cm. The gradient for the slope must be less than 1:12 Cost for bins is ?390 per 1100litre container and ?560 per Mini Recycling Centre."/>
Received Date	<input type="text" value="09/10/2017 10:29:06"/>
Attachments	