

# Consultee Comment for planning application 6/2018/0254/COND

<b>Application Number</b>	<input type="text" value="6/2018/0254/COND"/>
<b>Location</b>	<input type="text" value="Studio Four 37 Broadwater Road Welwyn Garden City AL7 3AX"/>
<b>Proposal</b>	<input type="text" value="Submission of details pursuant to condition 1 (material samples), 2 (hard and soft landscape), 3 (details regarding sedum roof), 4 (surface water drainage), 5 (construction management plan), 6 (bin storage) and 7 (cycle storage) on planning permission 6/2016/2497/MAJ, dated 16/05/2017"/>
<b>Case Officer</b>	<input type="text" value="Ms Louise Sahlke"/>
<b>Name</b>	<input type="text" value="Public Health and Protec"/>
<b>Address</b>	<input type="text" value="WHBC - Public Health and Protection"/>
<b>Type of Comment</b>	<input type="text" value="Object"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="In respect to condition 6- the applicant has not stated the intended operational hours of work. In Welwyn Hatfield we have strict operational hours and these are: The times permitted for noisy works are as follows: Monday to Friday 08:00 to 18:00. Saturday 08:00 to 13:00. No noisy works on Sundays or Bank Holidays. Requirements to carry out noisy works outside of these times must be requested by an application made under section 61 of the Control of Pollution Act 1974. Noisy works carried out beyond these times without consent may result in enforcement action. Please can the applicant include this information in their construction management plan."/>
<b>Received Date</b>	<input type="text" value="19/02/2018 10:00:46"/>
<b>Attachments</b>	