

# Consultee Comment for planning application 6/2018/0642/VAR

<b>Application Number</b>	<input type="text" value="6/2018/0642/VAR"/>
<b>Location</b>	<input type="text" value="37 Broadwater Road Welwyn Garden City AL7 3AX"/>
<b>Proposal</b>	<input type="text" value="Variation of condition 16 (approved plans) on planning permission 6/2016/2497/MAJ, dated 27/04/2017"/>
<b>Case Officer</b>	<input type="text" value="Ms Louise Sahlke"/>
<b>Name</b>	<input type="text" value="Lorraine Davis"/>
<b>Address</b>	<input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>
<b>Type of Comment</b>	<input type="text" value="ConditionalResponse"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="26/03/2018 - Lorraine Davis The Bin store would need to have double doors which open outwards. As advised in the original application the requirement will be for 4 x 1100 litre containers and 1 x MRC (mini recycling centre). The bin store on the documents here show 10 bins and a single door opening inwards, this needs to be revised. I would also like to see a swept path diagram showing the freighter entering and exiting the site in a forward motion, please use the Bin Store Planning Guidance for our vehicle dimensions. Thank You"/>
<b>Received Date</b>	<input type="text" value="26/03/2018 16:42:20"/>
<b>Attachments</b>	