

# Consultee Comment for planning application 6/2018/2387/MAJ

|                           |  |
|---------------------------|--|
| <b>Application Number</b> | <input type="text" value="6/2018/2387/MAJ"/>   |
| <b>Location</b>           | <input type="text" value="37 Broadwater Road Welwyn Garden City AL7 3AX"/>   |
| <b>Proposal</b>           | <input type="text" value="Construction of new build of 22 x 2 Bedroom and 2 x 3 Bedroom residential apartments with balconies and a roof garden. Layout of 26 car parking spaces, cycle parking, refuse store, internal access routes, landscaping and supporting infrastructure."/>   |
| <b>Case Officer</b>       | <input type="text" value="Ms Louise Sahlke"/>  |
| <b>Organisation</b>       | <input type="text" value="WHBC - Client Services"/>  |
| <b>Name</b>               | <input type="text" value="Lorraine Davis"/>  |
| <b>Address</b>            | <input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>   |
| <b>Type of Comment</b>    | <input type="text" value="Comment"/>   |
| <b>Type</b>               | <input type="text"/>   |
| <b>Comments</b>           | <input type="text" value="04/10/2018 - Lorraine Davis This can be incorporated on to our existing refuse &amp; recycling schedules. As advised on previous application (6/2018/0642/VAR) 4 x 1100l containers would be required at a cost of ?390 each. The bin store will require double doors opening outwards and a clear path with even surface and no kerbs to negotiate. Subsequent tracking diagram on previous application addressed these requests to our satisfaction If the developers wish to provide recycling facilities a Mini Recycling Centre can be installed within the bin store and this would accept glass/can and paper. the cost of this would be ?560.00. The dimensions of all containers and MRC are on our Bin Store Planning Guidance attached here."/> |
| <b>Received Date</b>      | <input type="text" value="04/10/2018 12:41:53"/>   |
| <b>Attachments</b>        | <input type="text" value="The following files have been uploaded:&lt;br/&gt;Bin store planning guidance_2015.docx"/>   |