

From: [Terry Vincent](#)
To: [Clare Howe](#)
Cc: [Planning](#)
Subject: Ref: 6/2019/0108/PN11
Date: 30 January 2019 13:35:53

Hi Clare,

I have looked at this application and the accompanying documents.

I have a couple of issues with the noise report and I wondered if you could kindly pass on these issues to the applicant.

I will need to see a BS4142:2014 noise assessment regarding the motor vehicle repair shop adjacent to the development site. I am concerned that this could have an impact on the closest façade of the proposed development. As there is some time before the deadline for this application I wanted to give the applicant a chance to submit the report before the consultation period expires.

I would also like the noise consultant to provide me with the 15minute LAeq data from the monitoring period.

If the applicant is unwilling to carry out a BS4142:2014 then I will be recommending refusal.

If you have any questions please let me know.

Thank you.

Kind Regards

Terry Vincent AMIOA
Environmental Health Technical Officer
Welwyn Hatfield Borough Council
Telephone: 01707 357 934
t.vincent@welhat.gov.uk
Working better, together

www.welhat.gov.uk
[@WelHatCouncil](#)
[Welwyn Hatfield Borough Council](#)