

Consultee Comment for planning application 6/2019/1788/COND

Application Number	<input type="text" value="6/2019/1788/COND"/>
Location	<input type="text" value="Former Shredded Wheat Site Broadwater Road Welwyn Garden City AL8 6UN"/>
Proposal	<input type="text" value="Submission of details pursuant to condition 5(Surface water Discharge) 6 (Drainage System) 52 (Provision of open space/play space)35 (Delivery of accessible Housing) 13 (Highways) 37 (Vehicle access Point to Pall Mall Site) 50 (Refuse Storage Arrangements)on planning permission 6/2018/0171/MAJ"/>
Case Officer	<input type="text" value="Ms A Christophi"/>
Organisation	<input type="text" value="WHBC - Client Services"/>
Name	<input type="text" value="Lorraine Davis"/>
Address	<input type="text" value="Client Services The Campus Welwyn Garden City AL8 6AE"/>
Type of Comment	<input type="text" value="ConditionalResponse"/>
Type	<input type="text"/>
Comments	<input type="text" value="29/07/2019 - Lorraine Davis The number of refuse 1100l containers allocated to each of the Bin stores for Block 10 & 11 is acceptable, however, there is no provision for the MRC's (Mini REcycling Centres) the dimensions of these being on the attached Bin Store Guidance document. Block 10A and 11A will require 2 MRC's each and 10B/C and 11B/C will require 1 each. The cost of the MRC's is ?560.00 each and 1100l containers ?390.00 each. Can you please supply diagram with drag distances from bin store to freighter annotated on . These are to be no more than 15m, however, our preference is 10m. Also please confirm that there will be dropped kerbs and minimum 2m wide smooth paths from store to freighter with no steep gradients as noted on the original application. We would also like confirmation that there will be dedicated bays/keep clear markings for collection vehicles to be able to access the areas as the majority of accesses are within the parking bay areas for the flats."/>
Received Date	<input type="text" value="29/07/2019 16:10:39"/>
Attachments	